

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**


No. F.6/DFS/MS/School/2021/WZ/ 782

Dated: 27/9/21

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya (old) located at Mundka, New Delhi-110041 comprised of two blocks Ground plus one upper floor only was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2018/2032 dated 05/09/2018. The premises was re-inspected by officer concern of this department on 09/09/2021 in the presence of Mr. Naveen Lakra of the school and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Director of Education Circular F.6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building/premises is fit for occupancy class "Educational Building" Group-B, as above with effect from27.9.21.....for a period of **Three years**, subject to the compliance of the conditions mentioned below.

Issued on 27/9/21 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Principal, Nigam Pratibha Kanya Vidyalaya (old), located at Mundka, New Delhi-110041.
2. The Director of Education, NDMC, Civic Centre, Minto Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Nigam Pratibha Kanya Vidyakaya located at Mundka, New Delhi-110041.		
2	Type of Occupancy	Group-B, "Educational Building" (School)		
3	Building Comprised of	02 Blocks- Ground Plus One upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DF'S/MS/School/WZ/2018/2032 dated 05/09/2018		
6	Fire Safety Directives Letter No	DOE Circular dated 01/03/2011		
7	Date of Inspection	09/09/2021		
8	Name of the Inspecting Officers	ADO Aman Kumar Lathar		
9	Name & Designation of Officers from the building side	Mr. Naveen Lakra (Teacher)		
10	Year of construction	2012		
11	Applicant letter No.	Email dated 18/08/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circ. Dt 01/03/2011 Requirements	Provided at Site	Remarks MR/NMR (old case)
1	Access to Building.			
	➤ Road width	6 m	6 m	MR
	➤ Gate width	4.5 m	4.5 m	MR
	➤ Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	1 in each block	2 in each block	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floor	1.50 m	1.90, 1.26 in 1 st block 1.51, 1.26 in 2 nd block	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	One in each block	Provided	MR
	e) Width of corridor	1.50 m	1.50 m	MR
	f) Door size	1.00 m	1.00 m (Double doors)	MR
3	Compartmentation.			
	➤ Fire check door.	-N/A-	-N/A-	-N/A-
	➤ Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	➤ Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	➤ Water curtain	-N/A-	-N/A-	-N/A-
	➤ Fire dampers.	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	➤ Basement	-N/A-	-N/A-	-N/A-
	➤ Upper floors	-N/A-	-N/A-	-N/A-
5.	Fire Extinguishers.			
	➤ Total numbers	05 nos	08 nos	MR
	➤ Types	ABC/CO ₂	Provided	MR
	➤ ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	➤ Total numbers on each floor.	-N/A-	-N/A-	-N/A-
	➤ Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	➤ Nozzle Diameter	-N/A-	-N/A-	-N/A-

Amman

1.
1
08)

7	Automatic fire detection & alarming system.			
	➤ Type of detectors	-N/A-	-N/A-	-N/A-
	➤ Location of Main Panel	-N/A-	-N/A-	-N/A-
	➤ Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	➤ Alternate source of power	-N/A-	-N/A-	-N/A-
	➤ Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	➤ Basement.	-N/A-	-N/A-	-N/A-
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	➤ Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	➤ Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	➤ Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	➤ Total number of hydrants.	-N/A-	-N/A-	-N/A-
	➤ Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	➤ Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	➤ Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	Exit Signage.			
16.	Provision of Lifts.			
	➤ Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	➤ Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	➤ Communication in lift car.	-N/A-	-N/A-	-N/A-
	➤ Fireman's switch.	-N/A-	-N/A-	-N/A-
	➤ Lift signage.	-N/A-	-N/A-	-N/A-

[Handwritten signature]

n/s

-N/A	17	Standby Power Supply	-N/A-	-N/A-	-N/A-
-N/	18.	Refuge Area			
-		➤ Total area	-N/A-	-N/A-	-N/A-
		➤ Location	-N/A-	-N/A-	-N/A-
	19.	Fire Control Room.			
		➤ Detector System Panel.	-N/A-	-N/A-	-N/A-
		➤ Flow Switch Panel.	-N/A-	-N/A-	-N/A-
		➤ PA system Panel.	-N/A-	-N/A-	-N/A-
		➤ Battery backup	-N/A-	-N/A-	-N/A-
		➤ Building floor plan	-N/A-	-N/A-	-N/A-
	20.	Special Fire Protection System for the Protection of special Risk, if any.	-N/A-	-N/A-	-N/A-

The fire protection system provided in the building were randomly tested/ checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011. FSC issued vide letter no. F.6/DFS/MS/School/WZ/2018/2032 dated 05/09/2018, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is prepared & put up for approval and signature please.

Signature of the Inspecting Officer
 Name : Aman Kumar Lathar
 Designation: ADO (JWP)

DO (WD)

148

16/09/21

16/9

DFS (WZ)

17/9/2021

ADO (JWP)

F.T. letter is put up for signature of.

DFS (WZ)

27/9/2021

28/09/21
ADO (JWP)

148/21