

55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2021/ 780

Dated: 27/9/21

FIRE SAFETY CERTIFICATE


Certified that the **Shaheed Bhai Bal Mukund, Govt. Sarvodaya Vidyalaya, Shankracharya Marg, Delhi-54**, comprised of ground + 01 upper floor only (old block), owned/occupied by **Shaheed Bhai Bal Mukund, Govt. Sarvodaya Vidyalaya**, has complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Delhi Fire Service on 26.08.2021 in the presence of Mr. Mahak Singh (Principal) and found that the school building comprised of **ground + 01 upper floor only** (old block) is fit for occupancy **group B 'Educational Building'** with effect from 27/9/21 for a period of three years, subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 27/9/21 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
Tel:-011-23414000

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi
2. The Principal
Shaheed Bhai Bal Mukund, Govt. Sarvodaya Vidyalaya, Shankracharya Marg, Delhi-54

slc 
24/9

Condition for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name and address of the building:	Shaheed Bhai Bal Mukund, Govt. Sarvodaya Vidyalaya, Shankracharya Marg, Delhi-54
2	Type of occupancy with details of floors:	Educational Building Group -B Old Block -G+1 upper floor
3	Type of case:	New case
4	Details of previous FSC:	NA
5	Fire safety directives no.:	F.16/Estate/fire safety/2011/3298-3398 dated 01.03.2011
6	Date of inspection:	14.09.2021
7	Name of the inspecting officer:	ADO Rajesh Kumar Shukla (SPM)
8	Name and designation of the officer from the building side:	Mr. Mahak Singh (Principal)
9	Year of construction:	Old Block 1968
10	Reference letter no.:	E-mail dated 06.07.2021

S.No	Minimum Standards on fire safety requirements as per circular no. F.16/Estate/fire safety/2011/3298-3398 dated 01.03.2011	Requirements	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	6 mtrs	6 mtrs	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of Staircase:			
		a) Upper floor	Old Block (G +1) - 2 nos.	Old Block (G +1) - 2 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase:			
		a) Upper floor	Old Block (G +1) - 1.5 mtrs. each	Old Block (G +1) - 2 nos. of 1.5 mtrs. each	MR
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire Check Door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. Of continuous staircase to terrace:	1 nos.	2 nos.	MR
	F	Width of the corridor	1.5 mtrs.	1.5 mtrs.	MR
	E	Door size	1 mtrs.	1 mtrs.	MR
3	Compartmentation:				
	A	Fire Check doors	NA	NA	NA
	B	Sealing of Electrical Shafts	NA	NA	NA
	C	Fire rating of shaft Doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke management System:				
	A	Upper floors	NA	NA	NA
	B	Basements	NA	NA	NA
5	Fire extinguishers				
	A	Total numbers	12 nos.	15 nos.	MR
	B	Types	CO2 , ABC	CO2, ABC	MR
	C	ISI marking	Required	Provided	MR

6	First Aid Hose reel				
	A	Total no. at each floor	NA	NA	NA
	B	Length of Hose Reel	NA	NA	NA
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of Detectors	NA	NA	NA
	B	Location of main Panel	NA	NA	NA
8	C	Location of Repeater Panel	NA	NA	NA
	D	Alternate power Source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
9	MOEFA		NA	Provided	NA
9	Public Address System		NA	Provided	NA
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper Floor	NA	NA	NA
11	C	Sprinklers above false ceiling	NA	NA	NA
	Internal hydrants				
	A	Size of the riser/down comer	NA	NA	NA
12	B	No. Of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
	Yard Hydrants				
13	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
	Pumping arrangements				
14	A	Ground Level			
		i) Discharge of main pump	NA	NA	NA
		j) Head of main pump	NA	NA	NA
		k) Number of main pump	NA	NA	NA
		l) Discharge of jockey pump	NA	NA	NA
		m) Head of jockey pump	NA	NA	NA
		n) Discharge of Standby pump	NA	NA	NA
		o) Head of Standby pump	NA	NA	NA
	p) Auto starting/ manual stopping	NA	NA	NA	
	B	Terrace Level			
		e) Discharge of terrace pump	NA	NA	NA
		f) Head of terrace pump	NA	NA	NA
		g) Alternate power supply	NA	NA	NA
		h) Auto starting of pump	NA	NA	NA
Captive Water Storage for Fire Fighting					
15	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	NA	NA	NA
16	Exit Signage		Required	Provided	MR
17	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		NA	NA	NA

18	Refuge Area			
	A	location	NA	NA
	B	Total area	NA	NA
19	Fire Control Room			
	A	Fire Detection System panel	NA	NA
	B	Flow switch panel	NA	NA
	C	P A system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plan	NA	NA
20	Special Fire Protection for special risk if any			

Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA)

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

In view substantial compliance of the minimum standards on fire prevention and fire safety required under the rules as per the directives of Education Department vide letter no. 16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011, issuance of PSC to Shaheed Bhai Balakund, Govt. Sarvodaya Vidyalaya, Shankracharya Marg is recommended.

Rk
20/9/21

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (SPM)

CD

21/9/21

Dy. CFS (MD2)

D. Kumar
21/9/21

CPD (10)

Deep
21/9

Dr. [Signature]
29/9/21

Any SPM / FI is put up for signatures pls

Director (DBS)
29/9/21

Rk
26/9/21