

1
637

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2021/ 256

Dated: 29/09/2021

FIRE SAFETY CERTIFICATE

Certified that M/s Yo Yo Bar (A unit of Yo Yo Restro & Party lounge) Located at, 1st floor, Unit No. F-1 to F-8, Plot No 25, Sector – 20, Dwarka, New Delhi 110075, is running at 1st floor in a building comprised of Ground + 03 Upper Floors was issued FSC vide Letter no. F6/DFS/MS/EH/2018/SZ/916 Dated 04/05/2018, The premises was re inspected by the officers concerned of this department on 18-09-2021 in the presence of Sh. Bhavesh Yadav and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" **Group D (1st Floor Only)** with effect from 29/9/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/9/21..... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
2. The Add. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
3. M/s Yo Yo Bar (A unit of Yo Yo Resto & Party lounge) Located at, 1st floor, Unit No. F-1 to F-8, Plot No 25, Sector – 20, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

W/19

INSPECTION REPORT

1. Name & address of the building: M/s Yo Yo Bar (A unit of Yo Yo Resto & Party lounge) Located at, 1st floor, Unit No. F-1 to F-8, Plot No 25, Sector – 20, Dwarka, New Delhi.

2. Type of Occupancy : Assembly D (Restaurant)

3. Type of Case : Renewal ((**Restaurant is running at 1st Floor** in a building comprised of Ground + Three Upper Floor)

4. Details of previous NOC: F6/DFS/MS/EH/2018/SZ/916 Dated 04/05/18

5. Fire Safety directives Letter No. : BBL-1983/NBC 2005 Part IV

6. Date of inspection : 18- 09 -2021

7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)

8. Name and designation of Officer
from the building side : Sh. Bhavesh Yadav

9. Year of Construction : Before 2010

10. Applicant's letter No. : 2021083119665 dated 10-09-2021

| Sr. No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/5 | Provided at site | Remarks MR/NMR |
|--------|---|------------|-----------------------------|----------------|
| 1. | Access of building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 9 mtr | Provided | MR |
| | | 4.5 m | Direct accessible from road | MR |
| | | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper floors Basements | 02 nos. | 02 nos | MR |
| | | NA | NA | NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper floors Basements | 2m & 1.25m | 02 mtr & 1.25 m | MR(Old Case) |
| | | NA | NA | NA |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | NA | NA | NA |
| | | NA | NA | NA |
| | d. No of continuous staircase to terrace | Required | 01 | MR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 01 mtr | 02 mtr & 1m | MR(Old Case) |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |

| | | | | |
|-----|--|---------------|--|----|
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 liters | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | Required | DG Set | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | ABC Fire Extinguisher provided near electric panel | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2018/SZ/916 Dated 04/05/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Wd. Vir Singh
 Designation ADD/DWR

Dotsu - om m/R K.T.
Dyefo/s2 dh

ADD/DWR

Sir AP letter is best up etc
 Sign by ADD/DWR
Dyefo/s2 dh M.S. 11/21