

C-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/GH/2021/SZ/ 439

Dated: 29/9/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s **The R Blues Guest House (A Unit of hotel The R Blues)** at A-79, NH-8, Mahipalpur Extn. New Delhi- 110037 comprised of Basement, ground plus two upper floors (Total- 13 Guest Room) was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2017/SZ/1347 dated 08/09/2017. The premise was re-inspected by the officer concerned of this department on 20/09/2021 in the presence of Mr. Vinod Sehrawat (Partner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential, Group-A**" (Guest House with 13 Guest rooms) as above with effect from 29/9/2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/9/21 /2021 at New Delhi by



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Manager, The R Blues Guest House (A Unit of hotel The R Blues) at A-79, NH-8, Mahipalpur Extn. New Delhi- 110037
2. The Addl. Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049 (Ref. MHA Portal ID No- 2021073016390 dated 30/07/2021)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. The provision's under clause 7.31 of UBBL-2016 shall be done in the building on or **before 30/09/2021** in compliance to the notification dated 27/05/2019 an as approved and now have been extended till 30.09 2021 vide Directorate of Local Bodies, UDD, GNCT of Delhi letter no. F5 (189)/AD/LB/2016/359-374 dated 29.06.2021.

M/15

### INSPECTION REPORT

1	Name & Address of the Building	M/s The R Blues Guest House (A Unit of hotel The R Blues) at A-79, NH-8, Mahipalpur Extn. New Delhi- 110037		
2	Type of Occupancy	Residential, "Group-A" (Guest House)		
3	Building Comprised of	Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/GH/2017/SZ/1347 dated 08/09/2017		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	20/09/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Vinod Sehrawat (Partner)		
10	Year of construction	2003	Total 13 Guest room	
11	Applicant letter No.	Online ID No 2021073016390 dated 30/07/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Required	06 mtr	MR
		-NA-	Directly accessible form road	-NA-
		-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Required	01 Nos	MR
	➤ Basement floor.	Required	02 Nos	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	1.03 mtr	MR
	➤ Basement floor	Required	1.03 & 0.87 mtr	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	01 Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1m	1.60 mtr (Final Exit)	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 APCH	-NA-	-NA-
5	<b>Fire Extinguishers.</b>			
	• Total numbers	12 Nos	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR



N/17

19	<b>Fire Control Room.</b>	• Detector system panel.	-NA-	-NA-	-NA-
		• Flow switch panel.	-NA-	-NA-	-NA-
		• PA system panel.	-NA-	-NA-	-NA-
		• Battery backup.	-NA-	-NA-	-NA-
		• Building floor plan.	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-	-NA-

The fire protection system provided in the premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/GH/2017/SZ/1347 dated 08/09/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Raj*  
23/9

Signature of the Inspecting Officer  
Name: - Rajesh Kumar  
Designation: - ADO/BCP

DO (SD)

*Raj*  
23/09/21

Defolby

*h* F.T.

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

*Raj*  
23/9

Defolby

*h*

M. S. cell