

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No.F6/DFS/MS/SZ/2021/ 259

Dated: 29/09/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Drink 'N' Dine Restaurant, Located at, Supreme Plaza, Shop No. 5,6,7, Plot No. 15-16, Sector – 6, Dwarka, New Delhi – 110075, is running at 3<sup>rd</sup> floor in a building comprised of Ground + 03 Upper Floors FSC issued vide letter no F6/DFS/MS/EH/2018/SZ/1417 Dated 18/06/2018. The premises was re – inspected by the officer concerned of this department on 20/09/2021 in the presence of Mr. Anil Negi (Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class “ Assembly” Group D (at 3<sup>rd</sup> floor only) with effect from 29/9/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/9/21..... at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
2. The Manager, M/S Drink 'N' Dine Restaurant, Located at Supreme Plaza, Shop No. 5,6,7, Plot No. 15-16, Sector – 6, Dwarka, New Delhi – 110075.

**Following fire safety directives must be adhered to:-**

1. **The FSC shall be null & void if terrace is being used for the restaurant.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

W 126

**INSPECTION REPORT**

1. Name & address of the building: M/S Drink 'N' Dine Restaurant, Located at Supreme Plaza, Shop No. 5,6,7, Plot No. 15-16, Sector – 6, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Class-D (Assembly)( Running At 3rd Floor in a building comprised of Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/EH/2018/SZ/1417 Dated 18/06/2018
5. Fire Safety directives Letter No. :Nil
6. Date of inspection : 20/09/2021
7. Name of the Inspecting Officer ; Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. Anil Negi (Manager)
9. Year of Construction : Before 2006
10. Applicant's L. No: Email dated 16/09/2021 & Application no 2021090219913

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17	Provided at site	Remarks
1.	Access of building			MR/NMR
	• Road width	09 mtrs	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Old case	01	MR( Old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25 mtr	1.25 mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	1.42 m	1.42 mtr	MR
	f. Door Size	90 cm X210 cm	<b>02 mtr( Including door Frame) &amp; 90 cm</b>	<b>MR(Old case)</b>
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



N/28

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	Old case	5,000 ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2018/SZ/1417 Dated 18/06/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note;- The Terrace shall be used as per BBL. The FSC shall be null & void if terrace is used for restaurant.**

Signature of the Inspecting Officer

Name

Designation

18/06/2018  
 Udai Vir Singh  
 AD/D/W/K

Dotsu - On M/R F.T.

Dyefo/s2 DA

AD/D/W/K