

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Incl./2021/WZ/ 479

Dated: 01/10/2021

FIRE SAFETY CERTIFICATE

Certified that the building at Plot no. C-2, Udyog Nagar, Rohtak Road, New Delhi-110041 comprised of Basement & Ground floor only owned/occupied by **Micro Footwears Pvt. Ltd.** has already been issued FSC by this department vide letter No F.6/DFS/MS/Incl./2018/1472 dated 22/06/2018. The premises was re-inspected by officer concerned of this department on 21/09/2021 in the presence of Mr. Dube (Plant Head) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules- 2010 and that premises/building is fit for occupancy class "Industrial" effect from ..01/10/2021.... for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 01/10/2021 at New Delhi by

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. Micro Footwears Pvt. Ltd., Plot no. C-2, Udyog Nagar, Rohtak Road, New Delhi-41.
2. The Executive Engineer (Bldg.), NDMC, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Micro Footwears Pvt. Ltd., Plot no. C-2, Udyog Nagar, Rohtak Road, New Delhi-41		
2	Type of Occupancy	Group-G (Industrial)		
3	Building Comprised of	Basement + Ground floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Indl./2018/1472 dated 22/06/2018		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2000/828 dated 09/05/2000		
7	Date of Inspection	21/09/2021		
8	Name of the Inspecting Officers	ADO Aman Kumar Lathar		
9	Name & Designation of Officers from the building side	Mr. Dube (Plant Head)		
10	Year of construction	2000		
11	Applicant letter No.	Email dated 15/09/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	06 m	06 m	MR
	➤ Gate width	5 m	5 m	MR
	➤ Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	2 nos	04 nos	MR
	b) Width of Staircase			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	Old case	1.75 m × 4	MR(old case)
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d)No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e)Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	1.20 m	1.50 m	MR
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	15 nos	30 nos	MR
	• Types	WCO ₂ /CO ₂ /DCP	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	2 nos	02	MR
	• Length of hose-reel hose.	30 m	30 m	MR
	• Nozzle Diameter	5 mm	5 mm	MR

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
8.	MOEFA	-N/A-	Provided	-N/A-
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground & Above floors 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	2	2	MR
	<ul style="list-style-type: none"> Hose box. 	2	2	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	4	4	MR
	<ul style="list-style-type: none"> Hose box 	4	4	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	Not mentioned in guidelines	2280 LPM	MR
	➤ Head of main pump.	Not mentioned in guidelines	60 MH	MR
	➤ Number of main pumps.	1	1	MR
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual Stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access	Required	Provided	MR
		Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	Not mentioned in guidelines	900 LPM	MR
	➤ Head of pump.	Not mentioned in guidelines	40 MH	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	1,00,000 ltrs	1,00,000 ltrs	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	NR	Provided	NR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	NR	Provided	NR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	25,000 ltrs	25,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Communication in lift car. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Fireman's switch. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Lift signage. 	-N/A-	-N/A-	-N/A-

17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	At DG set, Foam fire extinguisher required	Provided	MR

The fire protection system provided in the building were randomly tested/ checked and found functional at the time of inspection.

The shortcoming issued by this department vide letter No. F/6/DFS/MS/WZ/2021/1479 dated 29/07/2021 has been compiled by the building management.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F.6/DFS/MS/Indl./2018/1472 dated 22/06/2018, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

156
23/09/21

[Handwritten signature]
22/9/21

Signature of the Inspecting Officer
Name : Aman Kumar Lathar
Designation: ADO (JWP)

~~DO (WD)~~ *[Signature]* 23/9/2021
~~DCA (W2)~~

[Signature]
29/9/2021

~~ADP (JWP)~~

F.I. letter is put-up for signature Mr.

~~SCFO (W2)~~

[Signature]
30/9/2021

[Handwritten signature]
20/9/21
ADO (W2)

ms/ all