

C-60 -58

8/25/2021
CC-3866

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No.F.6/DFS/MS/EH/2021/SZ/ 266

Dated: 30/9/21

FIRE SAFETY CERTIFICATE

Certified that the M/s Talli Station running at second floor of a building comprised of basement, ground plus three upper floors located at J-2/11, Second Floor, B.K. Dutt Market, Rajouri Garden, New Delhi-110027, owned/occupied by M/s Talli Station have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 16/09/2021 in the presence of Sh. Chandpreet Singh and found that the building (Second Floor only) is fit for occupancy 'Group D "Assembly Building"(Restaurant) with effect from 30/9/21 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....30.9.21..... at New Delhi by


(Atul Garg)

Director

Delhi Fire Service
OK K

To,

The Manager, M/s Talli Station J-2/11, Second Floor, B.K. Dutt Market, Rajouri Garden, New Delhi-110027

Copy to:-

The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry

8/25/2021
Eating and Lodging License Login

Download all Attachment

Export to Excel

Renewal with Applicant

8/25/2021
Sheet
NARAYANA VIHAR

8/25/2021
Eating and Lodging License Login

N/8

INSPECTION REPORT

1. Name & address of the building: M/s Talli Station J-2/11, Second Floor, B.K. Dutt Market, Rajouri Garden, New Delhi-110027.
2. Building comprised of : Basement, ground +3 floors (Eating house at second floor only)
3. Type of Occupancy : Group D (Assembly Building) *Restaurant*
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 16/09/2021
8. Name of Inspecting Officers : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Chandpreet Singh
Year of Construction : 2012
10. Applicant's letter No. : ID No. 2021082518957 dated 25/08/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtrs 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No.'s N/A	02 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5 M & 1.0 M N/A	1.5 M & 1.0 M N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	Opening in hall	MR
	f. Door Size	1.5 M	1.5 M each	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural Ventilation	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 No.'s ABC/ CO ₂ ISI marked	Provided Provided ISI marked	MR MR MR

* Sealing Capacity is less than 150 Pans

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor & Upper floor Sprinkler above false ceiling 	N/A N/A N/A	N/A Provided N/A	N/A MR N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100 mm 01 No. 01 No.	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 40 mtrs Required Required	N/A 450 LPM Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A Required N/A 20,000 ltrs	N/A N/A Provided N/A 50,000 ltrs	N/A N/A MR N/A MR
15.	Exit Signage.	Required	Provided	MR


N/10


Provision of Lifts.		(No Lift)		
MR	• Pressurization of Lift Shaft	N/A	N/A	N/A
MR	• Pressurization of Lift lobby	N/A	N/A	N/A
MR	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
MR	• Lift Signage	N/A	N/A	N/A
N/A	Standby power supply	Required	Provided	MR
18. Refuge Area.				
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19. Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A


- (1) The total covered area of the ground floor restaurant is 111 sq. meters (Approx.) including sitting area, toilet area, kitchen area.
- (2) As per the NBC Part-IV, the number of occupants comes out to be approx 62 persons i.e. $(200/1.8=61.66)$


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was already issued vide letter no. F6/DFS/MS/EH/2018/SZ/4003 dated 25/09/2018 has been complied.


Keeping in view of the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.


 Signature of the Inspecting Officer
 Name :-R.K.Yadav
 Designation :-ADO(JKP)

DO (South West)  17/09/2021



Dy cfo (32)  21/9
 C.F.O.

The door size requirement at N/10 is different what has been mentioned at N/8. The sheet copy of c/51 are not complied as per The N/10 N/8 Tabulation  21/9