

59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 263

Dated: 30/09/2021

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Soy Soi (A Unit of Pricol Gourment Pvt Ltd.)** Shop No 227, 228, **First Floor**, DLF Place Saket, Delhi 110017 in the building comprised of 03 tiers Basement, Ground + 07 Upper Floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of department on 23/09/2021 in the presence of Sh. Nikesh Lamba and that the premise is fit for occupancy class **Group-D Assembly** (Eating House running at First floor only) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 30 / 09 /2021 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016 (Ref. MHA Portal ID No 2021080416760 dated 05/08/2021)
3. M/s Soy Soi (A Unit of Pricol Gourment Pvt Ltd.) Shop No 227, 228, **First Floor**, DLF Place Saket, Delhi 110017

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	M/s Soy Sol (A Unit of Pricol Gourment Pvt Ltd.) Shop No 227, 228, First Floor, DLF Place Saket, Delhi 110017		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant is running at 1 <sup>st</sup> Floor only)		
3	Building Comprised of	03 tier Basements, Ground + 07 Upper Floors		
4	Type of Case	New case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DLF Place Mall,- F.6/MS/DFS/BP/2005/2073 dated 04/10/2005 & F.6/MS/DFS/BP/2019/135 dated 01/04/2019		
7	Date of Inspection	23/09/2021		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Nikesh Lamba		
10	Year of construction	2006		
11	Applicant letter No.	MHA Portal ID No 2021080416760 dated 05/08/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>	( DLF Place Mall - F.6/DFS/MS/Mall/2019/SZ/1832 Dt. 23/09/2019)		
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Restt. within DLF Promenade Mall	Provided by Mall N/A N/A	MR N/A N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Upper floors.</li> <li>Basement floor.</li> </ul>	Restt within Mall N/A	As above N/A	MR N/A
	<b>b) Width of Staircase</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	Restt within Mall N/A	As above N/A	MR N/A
	<b>c) Protection of exits</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Restt within Mall Restt within Mall	As above As above	MR MR
	<b>d) No. of continuous staircase to terrace</b>	Restt within Mall	-NA-	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	02 required (1.50 m each)	1.50 m each	MR
3	<b>Compartmentation.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	Restt within Mall Restt within Mall N/A N/A N/A	As above As above N/A N/A N/A	MR MR N/A N/A N/A
4	<b>Smoke Management system.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	N/A Exhaust Fans Provided	N/A MR
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	Required ABC/CO <sub>2</sub> Required	08 Nos ABC & CO <sub>2</sub> Provided	MR MR MR
6	<b>First Aid Hose Reels.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	One near Restt 30m 5mm	As above As above As above	MR MR MR
7	<b>Automatic fire detection &amp; alarming system.</b>	(Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> </ul>	Required Required Required	Smoke & heat As above As above	MR MR MR

N-2

	<ul style="list-style-type: none"> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	Required	As above	MR
		Required	As above	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	As above	MR
10	<b>Automatic Sprinkler System</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>• Ground floor.</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>• Number of Hydrant per floor</li> </ul>	One near Restt	As above	MR
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	One near Restt	As above	MR
12	<b>Yard Hydrants.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	N/A	As above	N/A
13	<b>Pumping arrangements.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> </ul>	<b>Common pumping arrangements for entire bldg</b>		
	➤ Discharge of main pump.	4500 LPM	4500 LPM	MR
	➤ Head of main pump.	70m	70m	MR
	➤ Number of main pumps.	02 Nos.	02 Nos.	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	70m	70m	MR
	➤ Standby Pump output.	4500 LPM	2 X 4500 LPM	MR
	➤ Standby Pump head.	70m	70m	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> </ul>			
	➤ Discharge of pump.	450 LPM	As above	MR
	➤ Head of pump.	40 m	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14	<b>Captive water storage for fire fighting.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> </ul>	Required	3,70,000 Ltrs	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Overhead tank capacity.</li> </ul>	Required	30,000 Ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Pressurization of lift lobby.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Communication in lift car.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Fireman's switch.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Lift signage.</li> </ul>	N/A	As above	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Flow switch panel.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• PA system panel.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Battery backup.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>• Building floor plan.</li> </ul>	N/A	As above	N/A


N.3


19	Fire Control Room.	Provided & Maintained by DLF Place, Saket		
	Detector system panel.	N/A	As above	N/A
	Flow switch panel.	N/A	As above	N/A
	PA system panel.	N/A	As above	N/A
	Battery backup.	N/A	As above	N/A
	Building floor plan.	N/A	As above	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	As above	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.


  
 Signature of the Inspecting officer  
 Name: Sh. Sunil Chaudhary  
 Designation: Dy. CFO (SZ)

  
 Signature of the Inspecting Officer  
 Name: Sh. S. K. Dua  
 Designation: DO (South)

  
 Signature of The inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Designation: ADO (BCP)


CFO (HQ)



  
 Director  
 24/09/2021 FIPs

DLF/NDL

F. t. is put up for signature please.

  
 Director  
 30/9/2021



uploaded on MHA portal  
 30/9 S2