

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2021/SZ/

28/09/2021

Dated:

28/09/2021

FIRE SAFETY CERTIFICATE

Certified that the Prem Service Station (Retail outlet of B.P.C.L. Petroleum Class A & B located at J.B. Tito Marg, Andrews Ganj, New Delhi-110049, comprised of Ground Floor only owned / occupied by M/s Prem Service Station, was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/2018/SZ/1660 dated 16/07/2018. The premises was re-inspected by the officer concerned of Fire Service on 18/09/2021 in the presence of Sh. Rajiv Sethi (Partner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Mixed" (Petrol Pump & Service Station) with effect from 28/09/2021 for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/09/2021 **at New Delhi by.**


(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Territory Manager (Retail), B.P.C.L., Bijwasan Installation, Bijwasan, New Delhi-110061.
2. Sh. Rajiv Sethi (Partner), Prem Service Station (Retail outlet of B.P.C.L. Petroleum Class A & B at J.B. Tito Marg, Andrews Ganj, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:-

1. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical / electric spark should be allowed within the premises and its vicinity.
3. 04 no's of CO2 gas type ISI capacity of 4.5 kg, 02 no's of ABC stored pressure power type ISI capacity 05kg and 01 numbers of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
4. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable not passing across the licensed premises.
6. Work under procurement / installation mentioned in the undertaking shall be complied before the commencement of the plant. The same shall be get inspected from OISD under intimation to this department.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

2/9
INSPECTION REPORT

1. Name & address of the building : **M/s Prem Service Station (Retail outlet of B. P. C. L. Petroleum Class A & B at J.B. Tito Marg, Andrews Ganj, New Delhi-49.**
2. Type of Occupancy : **Mixed Occupancy (Petrol Pump & Service Station)**
3. Type of Case : **Renewal (Ground Floor only)**
4. Details of previous NOC : **F6/DFS/MS/2018/SZ/1660 dated 16/07/2018**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **18/09/2021**
7. Name of the Inspecting Officer : **A.D.O. (S.J.)**
8. Name and designation of Officer from the building side : **Sh. Rajiv Sethi (Partner)**
9. Year of construction : **1965**
10. Applicant's letter received through email ID-prembpel@hotmail.com dated 07/09/2021

S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	12 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	1	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	0.90m	0.90m	MR
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	Required	2 CO, DCP & ABC 16 fire buckets	MR
	• Types	ABC/DCP/ CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR

(Signature)

21/10

6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	✓ Head of main pump	N/A	N/A	N/A
	✓ Number of main pumps	N/A	N/A	N/A
	✓ Jockey pump out put	N/A	N/A	N/A
	✓ Jockey pump head	N/A	N/A	N/A
	✓ Standby Pump out put	N/A	N/A	N/A
	✓ Standby Pump Head	N/A	N/A	N/A
	✓ Auto Starting/Manual stopping	N/A	N/A	N/A
	✓ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	✓ Discharge of pump	NA	NA	NA
	✓ Head of the pump	NA	NA	NA
	✓ Power supply	NA	NA	NA
	✓ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	✓ Draw of connection	NA	NA	NA
	✓ Fire service inlet	NA	NA	NA
	✓ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

108

		21/11		
15	No Smoking Signage English & Hindi	Required	Provided	MR
			English & Hindi	
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA		NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2018/SZ/1660 dated 16/07/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
20/09/2011

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

~~DO (S.J.)~~

21/09/21

~~DFS (S.J.)~~

F.T.

22/9

DO S.O.

24/09

~~ADO (S.J.)~~

F.T. is added for sign. fl.

27/09/21