



C-16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 269

Dated: 1/10/2021

FIRE SAFETY CERTIFICATE

Certified that M/s **KFC Restaurant, Shop No C-5, Ground floor, Main Market, Malviya Nagar, New Delhi-110017** located at Ground floor in the building comprised of Basement, Ground plus Three upper Floor owned/ occupied by **(A Unit of Sapphire Foods India Pvt. Ltd)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 22/09/2021 in the presence of Ms Sweta (Manager) and that the premise is fit for occupancy class **Group-D Assembly (Restaurant at Ground Floor only)** with effect from 1/10/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 1/10/2021 at New Delhi by


(ATUL GARG)
DIRECTOR
out

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID No 2021091621613 dated 16/09/2021)
3. KFC Restaurant, Shop No C-5, Ground floor, Main Market, Malviya Nagar, New Delhi-110017

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	KFC Restaurant, Shop No C-5, Ground floor, Main Market, Malviya Nagar, New Delhi-110017		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, ground, plus 03 upper floors (restaurant running at ground floor only)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	NBC Part IV		
7	Date of Inspection	22/09/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms Sweta (Manager)		
10	Year of construction	2020		
11	Applicant letter No.	Online Id 2021091621613 dated 16/09/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restaurant N/A N/A	6 mtr N/A N/A	MR N/A N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	N/A N/A	N/A N/A	N/A N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Exit (1.5 m each)	1.80 mtr & 1.50 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	04 Nos ISI marked	06 Nos. ABC-04, W.CO ₂ -02 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	Required 30m 5mm	Provided Provided Provided	MR MR MR
7	Automatic Fire Detection and Alarming system.			

N/A

	• Flow Switch Panel	N/A	N/A	N/A
	• PA system Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A
		N/A	N/A	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 401 dated 15/09/2021

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

[Signature]
 Signature of the Inspecting Officer
 Name Sh. Rajesh Kumar
 Designation: ADO (BCP)

~~DO (South)~~

[Signature]
28/09/21

~~DeFO (S)~~

[Signature]
27/9

~~C.F.~~

[Signature]
28/9

[Signature]
30/9/2021

~~Am/BCP~~

As approved F.S. letter is put up for your signature pl.

Director

[Signature]
01/10/2021

