

No.F6/DFS/MS/School/NDZ/2021/ 807

Dated: 11/10/21

FIRE SAFETY CERTIFICATE

Certified that the **Hakim Ajmal Khan Girls Sr. Sec. School, Darya Ganj, New Delhi-02**, comprised of ground + 02 upper floor (school running on 1st floor half only), **Ground floor- Orphanage, 1st floor - Half School & Half Central Haj Committee of India, 2nd floor- 2 rooms used as Orphanage storage**, owned/occupied by **Hakim Ajmal Khan Girls Sr. Sec. School** has complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Delhi Fire Service on 27.09.2021 in the presence of Dr. Shabnam Khanam, (Vice Principal) and found that the School building at 1st floor half is fit for occupancy **group B 'Educational Building'** with effect from 11.10.21 for a period of three years, subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 11/10/21 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
Tel:-011-23414000

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal,
Hakim Ajmal Khan Girls Sr. Sec. School, Darya Ganj, New Delhi-02.

Condition for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

ofc 
01.10.21

73

INSPECTION REPORT

1	Name & address of the building	Hakim Ajmal Khan Girls Sr. Sec. School, Darya Ganj, New Delhi-02.				
2	Building is comprised of	Ground + 02 upper floor (school running on 1 st floor half only) Ground floor- orphanage 1st floor - half school & half Central Haj Committee of India 2nd floor- 2 rooms (orphanage storages)				
3	Type of Occupancy	Educational				
4	Type of Case	New case				
5	Details of Previous FSC	No				
6	Fire Safety direction letter No	F16/Estate/cc/fire safety/2011/3298 to 3398 dated 01.03.2011				
7	Date of Inspection	27.09.2021				
8	Name of the Inspecting Officers	Rajesh Kumar Shukla ADO (SPM)				
9	Name of the designation of Officer from the building side	Dr. Shabnam Khanam, (Vice Principal)				
10	Year of Construction	1974				
11	Applicant's letter No	E-mail dated 18.09.2021				
S.No	Minimum Standards on fire Prevention and fire safety requirements as per circular no. 3298 to 3398 dated 01.03.2011.	Requirement as education circular	Provided at site	Remarks MR/NMR		
1	Access to building.					
	Road width	6 mtrs.	06mtrs.	MR		
	Gate width	NA	NA	NA		
	Width of internal road	NA	NA	NA		
2	Number, Width, Type and Arrangement of Exits.					
	A	Number of staircases				
		a	Upper floor	01 nos.	03 nos. 01 nos. =G+2 02 nos. =G+1	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	1.5 mtrs.	G+2 = 1.12 to 1.17 mtrs. G+1= 1.5 mtrs. each	MR
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace				
				01 nos.	01 nos.	MR
	E	Width of corridor				
				1.5 mtrs.	1.5 mtrs.	MR
G	Door size					
			1 mtrs.	1 mtrs.	MR	
3	Compartmentation.					
	A	Fire check door				
				NA	NA	NA
	B	Sealing of electrical shafts				
				NA	NA	NA
	C	Fire rating of shaft door				
			NA	NA	NA	
D	Water curtain					
			NA	NA	NA	
E	Fire dampers					
			NA	NA	NA	
4	Smoke Management System.					
	A	Basement				
				NA	NA	NA
B	Upper floor					
			NA	NA	NA	

5.	Fire Extinguisher.			
A	Total numbers	06 nos.	06 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
A	Total numbers	NA	NA	NA
B	Length of hose reel hose	NA	NA	NA
C	Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	MOEFA.	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic sprinkler system.			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants.			
A	Size of riser/ down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	Yard Hydrants.			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements.			
I.	Ground level			
A	Discharge of main pump	NA	NA	NA
B	Head of main pump	NA	NA	NA
C	Number of main pumps	NA	NA	NA
D	Jockey pump out put	NA	NA	NA
E	Jockey pump head	NA	NA	NA
F	Standby pump out put	NA	NA	NA
G	Standby pump head	NA	NA	NA
H	Auto starting /manual stopping	NA	NA	NA
I	Pump house access	NA	NA	NA
II.	Terrace Level			
A	Discharge of pump	NA	NA	NA
B	Head of the pump	NA	NA	NA
C	Power supply	NA	NA	NA
D	Auto starting of pump	NA	NA	NA


14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	NA	NA	NA
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby power supply.		NA	NA	NA
18	Refuge Area.				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room.				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	Pa system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:			N.A	NA

Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA)

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. The shortcomings issued vide letter no.F6/DFS/MS/2007/2404 dated 30.08.2007 has been rectified by the school management.

The Vice Principal has submitted an undertaking on 28.09.2021 two rooms at second floors use for storage of Orphanage.

In view substantial compliance of the minimum standards on fire prevention and fire safety required under the rules as per the directives of Education Department vide letter no. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011, issuance of FSC to **Hakim Ajmal Khan Girls Sr. Sec. School, Darya Ganj, New Delhi-02** is recommended.



28/9/21


Signature of the Inspecting Officer


Name Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CD)



29/9/21


Dy. Chf. (CD)


29/9/21


CFO (CD)


30/9


31/9/21


ADP/SPM

