

C-13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. DFS/MS/School/WZ/2021/ 806


Dated: 1/10/2021

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Co-ed. Sr. Sec. School (ID-1411123), Located at C-Block, Saraswati Vihar, Delhi-110034, comprised of Three Blocks (Ground + 01 Upper Floor) was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2018/WZ/2027 dated 04.09.2018.

Management has constructed a M. P. Hall & have complied with the fire prevention and fire safety requirements in accordance D.O.E Cr. No. 3298 to 3398 dated 01.03.2011 and Verified by the officer concerned of Fire Service on 21.09.2021 in the presence of Sh. R.K. Sharma (HOS), and that the premises/building is fit for occupancy class "Educational" Group B (Three Blocks - Ground + 01 Upper Floor & M. P. Hall) with effect from 1/10/21 for a period of three years, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 1/10/21 at New Delhi by


(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education Old Secretariat, Delhi - 110054.
2. The Principal, Govt. Sarvodaya Co-ed. Sr. Sec. School (ID-1411123), Located at C-Block, Saraswati Vihar, Delhi-110034.

Following fire safety directive must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: - **Govt. Sarvodaya Co.-ed. Sr. Sec. School (ID-1411123) Located at C-Block, Saraswati Vihar, Delhi-110034.**
2. Type of Occupancy: Educational 03 blocks (Ground + 01 Upper Floor & a new M.P. Hall 24x48 m)
3. Type of Case : Renewal/addition M.P. Hall
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/2027 dated 04.09.2018
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 21.09.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. R.K. Sharma (HOS)
9. Year of Construction : 2015
10. Applicant's letter No. : email dated 10.09.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/letter dated 04.09.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL(A-4, B-2 & C-1)	10 nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	BL-A=6X155 cm BL-B=2X148 cm & 1X153 cm BL-C=1X150 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	BL-A=170 cm BL-B=220 cm BL-C=173 cm	NA
	f. Door Size	1 m	103 cm & 116 cm (Include Door Frame)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

1-6

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	27 nos. ABC & CO ₂ ISI marked	56 nos. Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA

2

➤ Location		NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- Management has constructed a M. P. hall 24x48 m & have provided 08 nos. exit doors 02 m wide each & have complied all fire safety measures.


In view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, grant of Fire Safety Certificate is recommended.

230
23/09/21

[Signature]
23/9/21
S.P. Bhardwaj
ADO (WP)

~~*[Signature]*~~

~~*[Signature]*~~
23/9



~~*[Signature]*~~
27/9/21

[Signature]
27/9/2021

[Signature]

[Signature]
27/9

[Signature]
20/9/2021

A no/ WP

AT is put up for signature plan

[Signature]
11/10/2021

[Signature]
30/9/21