

2142

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F6/DFS/MS/GH/2021/SZ/ 459

Dated: 30/9/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s **BMK Guest House (Formerly Bright Star Inn-II)** located at **B-2, Greater Kailash Enclave-I, New Delhi 110048**, comprised of Basement (Vacant), ground plus three upper floors (Total- 30 Guest Room) was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2017/SZ/1229 dated 18/08/2017. The premise was re-inspected by the officer concerned of this department on 25/09/2021 in the presence of Sh. GBS Sehgal (owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential, Group-A**" (Guest House with 30 Guest rooms) as above with effect from 30/9/2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/9/2021 at New Delhi by

  
(SUNIL CHAUDHARY)  
**DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The Manager M/s BMK Guest House (Formerly Bright Star Inn-II) located at B-2, Greater Kailash Enclave-I, New Delhi 110048.
2. The Addl. Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049 (Ref. MHA Portal ID No- 2021021210376 dated 21/02/2021)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. The provision's under clause 7.31 of UBBL-2016 shall be done in the building on or **before 30/09/2021** in compliance to the notification dated 27/05/2019 as approved and now have been extended till 30.09 2021 vide Directorate of Local Bodies, UDD, GNCT of Delhi letter no. F5 (189)/AD/LB/2016/359-374 dated 29.06.2021.

**INSPECTION REPORT**

1	Name & Address of the Building	M/s BMK Guest House, B-2, Greater Kailash Enclave-1, New Delhi 110048		
2	Type of Occupancy	Residential, "Group -A" (Guest House)		
3	Building Comprised of	Basement, Ground + 03upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/GH/2017/SZ/1229 dated 18/08/2017		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	25/09/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. GBS Sehgal (owner)		
10	Year of construction	2006   Total 30 Guest room		
11	Applicant letter No.	Online ID No 2021021210376 dated 21/02/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Required -NA- -NA-	09 mtr -NA- -NA-	MR -NA- -NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Required	02 Nos	MR
	➤ Basement floor.	Required	02 Nos	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	1.25 mtr & 1.0 mtr	MR (old case)
	➤ Basement floor	Required	1.25 mtr & 1.0 mtr	MR (old case)
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	Two Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1m	1.20mtr (Final Exit)	MR
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers</li> </ul>	Required -NA- -NA- -NA- -NA-	Provided in basement -NA- -NA- -NA- -NA-	MR -NA- -NA- -NA- -NA-
<b>4</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	30 ACPH -NA-	Exhaust fan provided -NA-	MR -NA-
<b>5</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	10 Nos ABC / CO2 ISI marked	Provided ABC & CO2 Provided	MR MR MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	One 30 mtr 5 mm	Provided Provided Provided	MR MR MR

M/M

7	Automatic fire detection & alarming system.	Circular dated 29/06/2021 amendment / modification in (UBBL-2016 till 30/09/2021)		
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors.	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	20,000 ltr	Provided	MR
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 ltrs	10,000 ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

2/20

Modification in  
-NA-  
-NA-  
NA-  
A-  
-

19	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel	-NA-	-NA-	-NA-
	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-

The fire protection system provided in the premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No F6/DFS/MS/GH/2017/SZ/1229 dated 18/08/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*[Handwritten signature]*  
2/20

Signature of the Inspecting Officer  
Name: - Rajesh Kumar  
Designation: - ADO/BCP

~~DO (SD)~~

*[Handwritten signature]*  
28/09/21

~~DeFO (SF)~~


F.T.  
*[Handwritten signature]*

*[Handwritten signature]*  
ADO/BCP

As approved, f.t. letter is put up for your signature.

*[Handwritten signature]*  
30/9

*[Handwritten signature]*  
By ADO/BCP



M.S. Ull