

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

F.6/DFS/MS/EH/2021/SZ/ 272

Dated: 5/10/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s Guru Prasad Udupi Restaurant, DDA Shopping Complex, Phase-II, Munirka, New Delhi-110067** comprised of **Basement, ground plus one upper floors** (Restaurant running at First floor only) owned/occupied by Ms. Meghna (owner) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2017/SZ/831 dated 09/06/2017. The restaurant premise was re-inspected by the officer concerned of this department on 29/09/2021 in the presence of Ms. Meghna (owner) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 5/10/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 5/10/2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2021081617883 dated 10/09/2021)
3. M/s Guru Prasad Udupi Restaurant, DDA Shopping Complex, Phase-II, Munirka, New Delhi-110067.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Guru Prasad Udipi Restaurant, DDA Shopping Complex, Phase-II, Munirka, New Delhi-110067		
2	Type of Occupancy	Group-D Assembly Building (Restaurant)		
3	Building Comprised of	Basement, Ground + one upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2017/SZ/831 dated 09/06/2017		
6	Fire Safety Directives Letter No	Cir. No 4/22/2004/HP-III/356-369 dt 22/03/2005		
7	Date of Inspection	29/09/2021		
8	Name of the Inspecting Officers	Sh Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Meghna (Owner)		
10	Year of construction	2005		
11	Applicant letter No.	MHA Portal ID 2021081617883 dated 10/09/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC- 2007	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	6 mtr	Provided	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	Number of Staircase			
	Upper floors.	Required	01 + 01 ramp	MR
	Basement floor.	Required	01 + 01 ramp	N/A
	Width of Staircase			
	Upper floors	Required	1.40m & 2.0 m (ramp)	MR
	Basement floor	Required	1.50 m & 2.30m (ramp)	MR
	Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	No. of continuous staircase to terrace	Required	01 No	MR
	Width of corridor	N/A	N/A	N/A
	Door size	Required	1.7, 1.0 m & 1.0 mtr	MR (old case)
3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	12 ACPH	Exhaust fan provided	MR
	Upper floors	12 ACPH	Exhaust fan provided	MR
5	Fire Extinguishers.			
	Total numbers	13 Nos	13 Nos	MR
	Types	ABC/CO ₂	ABC & CO ₂	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	02 near restt.	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater Panel	N/A	N/A	N/A

	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	Basement	N/A	Others	N/A
	Ground floor & upper floor	N/A	Provided in rest	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of Riser/Down-comer	Required	Provided	MR
	Number of Hydrant per floor	N/A	Provided	N/A
	Hose box	N/A	Provided	N/A
12	Yard Hydrants			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	N/A	N/A	N/A
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	450 & 225 LPM	900 LPM	MR (old case)
	Head of pump.	40m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	Required	Provided	MR
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	5,000 Ltrs	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A

N/11

N/A
N/A
MR
N/A

	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2017/SZ/831 dated 09/06/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Handwritten signature
13/9/21

Signature of the Inspecting Officer
Name: - Sh. Rajesh Kumar
Designation: - ADO/BCP

DO (SB)

Handwritten signature
30/09/21

DeFO (2) F.T.

Handwritten signature

ADO (BCP)

As approved, F.T. letter is put up for your signature pl.

Handwritten signature
01/10/2021

Dy. CF/S2
Handwritten signature

Handwritten signature
M. S. Ull