

645

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F6 /DFS/MS/EH/NDZ/2021/ 275

Dated: 05/10/21

Fire Safety Certificate

Certified that the restaurant in the name and style of **Mc Donald's** running at **ground and 1st floor at DMRC Station, ISBT, Kashmere Gate, Delhi** which is comprised of Basement + ground + 02 upper floors is owned/ occupied by Mc Donald's and was granted FSC by this department vide letter no **F6/DFS/MS/EH/NDZ/2018/2322 dated 15.10.2018**. The premises was re-inspected by the officer concerned of this department on 27.09.2021 in presence of Mr. Vikas Kumar (Manager) and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Group D (**Assembly Building, Restaurant**) with effect from ..05.10.21..... for a period for three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules 2010 printed below.

Issued on05.10.21..... at New Delhi by


S.K. Tomar
05/10/21

(Dr. S. K. Tomar)

Dy. Chief Fire Officer

Tel: 011 - 23412025

Copy to:

1. The Joint Commissioner of Police (Licensing), 1st floor, P. S. Defence Colony, New Delhi w. r. to application no.202108251898 dated 25.08.2021.
2. The Manager, Mc Donald's Family Restaurant, ground & 1st floor, Kashmere Gate Metro Station, ISBT, Kashmere Gate, Delhi.

Conditions for validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
 2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
 3. The trained fire fighting staff should be available round the clock.
 4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
 5. The basement shall only be used as per BBL 1983.
 6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
 7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
 8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
 9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry
- Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained there to before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	M/s Mc Donald's Family Restaurant, at DMRC Station, ISBT, Kashmere Gate, Delhi.
2.	Type of occupancy with details of floors:	Basement + ground + 02 upper floors Restaurant running at Ground & 1 st floor only.
3.	Type of case:	Renewal
4.	Details of previous FSC:	F6/DFS/MS/EH/NDZ/2018/2322 dated 15.10.2018.
5.	Fire safety directives no.:	Nil.
6.	Date of inspection:	27.09.2021.
7.	Name of the inspecting officer:	ADO Rajesh Kumar Shukla.
8.	Name and designation of the officer from the building side:	Manager
9.	Year of construction:	-
10.	Reference letter no.:	Online ID no. 2021082518998 dated 25.08.2021

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (as per previous inspection reports)	Provide at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	06 mtrs.	12 mtrs.	MR
	B Gate width	NA	NA	NA
	C Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:			
	A No. of Staircase:			
	a) Upper floor	2 nos.	2 nos.	MR
	b) Basements	NA	NA	NA
	B Width of the Staircase:			
	a) Upper floors	1.5 mtrs	1.5 mtrs.	MR
	b) Basements	NA	NA	NA
	C Protection of Exits			
	a) fire check door	NA	NA	NA
	b) pressurization	NA	NA	NA
	D No. of continuous staircase to terrace	NA	NA	NA
	E Width of the corridor	NA	NA	NA
	F Door size	NA	NA	NA
3	Compartmentation:			
	A Fire check doors	NA	NA	NA
	B Sealing of horizontal & vertical opening	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke management System:			
	A Basements	NA	NA	NA
	B Upper floors	12 ACPH	Exhaust fan	MR
5	Fire extinguishers:			
	A Total numbers	06 no.	06 no.	MR
	B Types	ABC + CO ₂	ABC + CO ₂	MR
	C ISI marking	ISI marked	ISI marked	MR

6	First Aid Hose reel:			
A	Total no. at each floor	01 no.	01 no.	MR
B	Length of hose reel	30 m	30 m	MR
C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS):			
A	Type of detectors	NA	Provided	MR
B	Location of main panel	NA	Provided at ground floor	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate power source	NA	NA	NA
E	Hooter's location	NA	At both floors	NA
8	MOEFA:	Required	Provided	MR
9	Public Address System:	NA	NA	NA
10	Automatic Sprinkler System:			
A	Basement	Required	Provided	MR
B	Ground & upper floor	Required	Provided	MR
C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants:			
A	Size of down comer	100 mm	100 mm	MR
B	No. of hydrants per floor	1 no.	1 no.	MR
C	Hose box per floor	1 no.	1 no.	MR
12	Yard Hydrants:			
A	Total no. of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping arrangements:			
A	Ground Level			
	a) Discharge & head of main pump	NA	NA	NA
	b) Number of main pump	NA	NA	NA
	c) Discharge & head of jockey pump	NA	NA	NA
	d) Discharge & head of standby pump	NA	NA	NA
	e) Auto starting/ manual stopping	NA	NA	NA
B	Terrace Level			
	a) Discharge of terrace pump	450 LPM	450 LPM	MR
	b) Head of terrace pump	40m	40m	MR
	c) Alternate power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	NA	NA	NA
B	Draw off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
E	Access to tank	NA	NA	NA
D	Overhead tank capacity (combined)	10,000 Liters	Provided	MR
		Required	Provided	MR
15	Exit Signage:			
16	Provision of lift:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:	Required	Provided	MR

2/23

18	Refuge Area:			
	A	location		
	B	Total area	NA	NA
19	Fire Control Room:			
	A	Fire detection system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	P a system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plan	NA	NA
20	Special Fire Protection for special risk if any			
	A	Special Fire Protection system for Protection of Special Risk, if any:		NA

Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA) Provide but not functional (PNF).

The fire protection systems provided in the building were tested checked and found not functional at the time of inspection. The eating house portion at 1st floor has independent entry / exits and the same does not have direct connection with the restaurant portion at ground floor.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/EH/NDZ/2018/2322 dated 15.10.2018 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

[Signature]
29/9/2021

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CD)

[Signature]
4/10/21

[Signature]
4/10/21

[Signature]
4/10/21

[Signature] For use put up for signatures pls

[Signature]
04/10/21

[Signature]

[Signature]
11/10/21

MS

