

C-28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/EH/SZ/2021/ 276

Dated..05/10/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s McDonald's Family Restaurant, (Ms Connaught Plaza Restaurant Pvt. Ltd) H-12A, Kalkaji, New Delhi -110019** comprised of Ground plus two upper floor & Barsati Floor owned/occupied by M/s Connaught Plaza Restaurant Pvt. Ltd. The restaurant running at ground & First Floor was issued FSC by this department vide letter no. F6/DFS/MS/EH/2018/SZ/2059 dated 10/09/2018. The restaurant premise was re-inspected by the officer concerned of this department on 24/09/2021 in the presence of Sh. Sandeep Kumar (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 05/10/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/10/2021 at New Delhi by



**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

1. The Joint C.P (Lic) First Floor, PS Defence Colony, New Delhi – 110049.
2. The Dy. Health Officer, Health Department, South MCD, Green Park, New Delhi. (Ref. MHA Portal ID 2021082619164 dated 26-08-2021)
3. M/s McDonald's Family Restaurant, (Ms Connaught Plaza Restaurant Pvt. Ltd) H-12A, Kalkaji, New Delhi -110019

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	McDonald's Family Restaurant, (Ms Connaught Plaza Restaurant Pvt. Ltd)H-12A, Kalkaji, New Delhi -110019		
2	Type of Occupancy	Assembly 'Group-D'		
3	Building comprised of	(Restaurant running at first floor only)		
4	Type of Case	Ground plus 02 upper floor + Barsati Floor		
5	Details of Previous NOC	Renewal		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2018/SZ/2059 dated 10/09/2018		
7	Date of Inspection	Nil		
8	Name of the Inspecting Officers	24.09.2021		
9	Name & Designation of Officers from the building side	Rajesh Kumar/ ADO (BCP)		
10	Year of construction/ date of conversion	Sh. Pardeep Kumar (Manager)		
11	Applicant letter No.	2004		
		MHA Portal ID 2021082619164 dated 26-08-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC	Provided at Site	Remarks
1	Access to Building.			
	• Road width	4.50 mtr	12 mtr	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02 Nos	02 Nos	MR
	• Basement floor	NA	NA	-NA-
	b. Width of Staircase			
	• Upper floors	1.50 mtr	1.50 m & 1 m	MR
	• Basement floor	NA	NA	-NA-
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	NA	-NA-
	d. No. of continuous staircase to terrace	Required	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	02 exits (1.50 m)	2 m & 1.0 m	MR (old case)
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	08 Nos	08 Provided	MR
	• Types	ABC / CO2	W co2, ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Smoke type	MR
	• Location of Main Panel	Required	Ground floor	MR

M13

10 19

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooper's location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System	-NA-	NA	-NA-
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	NA	-NA-
11	Internal Hydrants.	Required	Provided	MR
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	NA	-NA-
12	Yard Hydrants.	-NA-	NA	-NA-
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
13	Pumping arrangements.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump House Access 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 & 180 LPM	450 LPM	MR
		35 m	35mtr	MR
		Required	Provided	M/R
		Required	Provided	M/R
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	M/R
		-NA-	-NA-	-NA-
		10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/4

N/A
MR
MR
R

19	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2018/SZ/2059 dated 10/09/2018 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
27/8

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (SD)

Ring
28/09/21

DO (SD) F.F.

[Signature]

ADO (BCP)

As approved, F.F. letter is put up for your signature.

1/4
30/09/2021

DO (SD) *[Signature]*

M.S. Cell