

c-44

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**


No. F6/DFS/MS/School/WZ/2021/ 814

Dated: 5/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Vishal Bharati Senior Secondary School, Located at P.S-Block, Zone H-4 & 5, Pitampura, Delhi – 110034, comprised of Ground + 03 Upper Floors only were issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2017/WZ/1724 Dated 01.12.2017. The said premises were re-inspected by the officer concerned of this department on 24.09.2021 in the presence of Sh. Ajit Singh (Manager) and found that the premises / buildings have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and found that the premises/building is fit for occupancy "Educational" Group B with effect from 5/10/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 5/10/21 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to :-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Vishal Bharati Senior Secondary School, Located at P.S-Block, Zone H-4 & 5, Pitampura, Delhi – 110034

**Following fire safety directive must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

N/20  
**INSPECTION REPORT**

1. Name & address of the building: **Vishal Bharati Senior Secondary School** Located at **P.S. Block, Zone H-4 & 5, Pitampura, Delhi-110034.**
2. Type of Occupancy : Educational (Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2017/WZ/1724 Dated 01.12.2017
5. Fire Safety directives Letter No. : D.O.E Cir. 262-362 dated 17-01-2005
6. Date of inspection : 24.09.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Ajit Singh (Manager)
9. Year of Construction : 2002-2005
10. Applicant's letter No. : email dated 16.09.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cir.No.262-362 dated 17-01-2005/letter dated 01.12.2017	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 x 1.5 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	14 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7. Automatic fire detection and alarming system			
• Type of detectors	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA
8. MOFFA	NA	NA	NA
9. Public Address System	Required	Provided	MR
10. Automatic Sprinkler System			
• Basements	NA	NA	NA
• Upper Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA
11. Internal Hydrants			
• Size of riser down- comer	100 mm	Provided	NA
• Number of hydrants per floor	03	Provided	NA
• Hose Box	Required	Provided	NA
12. Yard Hydrants			
• Total number of hydrants	Required	Provided	NA
• Hose Box	Required	Provided	NA
13. Pumping Arrangements			
• Ground Level			
• Discharge of main pump	NA	NA	NA
• Head of main pump	NA	NA	NA
• Number of main pumps	NA	NA	NA
• Jockey pump out put	NA	NA	NA
• Jockey pump head	NA	NA	NA
• Standby Pump out put	NA	NA	NA
• Standby Pump Head	NA	NA	NA
• Auto Starting Manual stopping	NA	NA	NA
• Pump House Access			
• Terrace level	NA	NA	NA
• Discharge of pump			
	450 lpm & 180 lpm	2x450 lpm	MR
• Head of the pump	40 m	Provided	MR
• Power supply	Required	Provided	MR
• Auto starting of pump	Required	Provided	MR
14. Captive water Storage for firefighting:			
• Underground tank capacity	NA	NA	NA
• Draw off connection	NA	NA	NA
• Fire service inlet	NA	NA	NA
• Access to tank	NA	NA	NA
• Overhead Tank capacity	5,000 ltrs.	Provided	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
• Pressurization of Lift Shaft	NA	NA	NA
• Pressurization of lift lobby	NA	NA	NA
• Communication in lift Car	NA	NA	NA
• Fireman's Grounding Switch	NA	NA	NA
• Lift Signage	NA	NA	NA
17. Standby power supply	NA	NA	NA
18. Refuge Area			
• Total area	NA	NA	NA
• Location	NA	NA	NA
19. Fire control room			
• Detector system panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA

*Pr*

20	Special Fire Protection Systems for Protection of special Risks, if any;	N/22 NA	NA	NA
----	--	------------	----	----

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E Cir. No. 262-362 dated 17-01-2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/SCHOOL/2017/WZ/1724 Dated 01.12.2017 is recommended.

~~DO/WZ~~

S.P. Bhardwaj  
ADO (WP)  
28/9/21

~~DO~~  
28/9/2021

DOFO (H2)

~~DO~~  
30/9/2021

~~ADO/WZ~~

FF for signature

DOFO WZ

~~DO~~  
4/10/2021

~~DO~~  
30/9/21

MS/cell