

CS

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 282

Dated: 8 / 10 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s Side car ( A unit of barkeepers LLP), Plot No M-29, M Block Market, GK-2, New Delhi-110048 located at 1<sup>st</sup> & 2<sup>nd</sup> upper floor in the building comprised of Basement, Ground plus Two upper Floor owned/ occupied by (a unit of Barkeepers LLP) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 05/10/2021 in the presence of Mr. Kuldeep Singh and that the premise is fit for occupancy class **Group-D Assembly (Restaurant at 1<sup>st</sup> & 2<sup>nd</sup> upper floor only)** with effect from 8 / 10 / 2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 8 / 10 / 2021 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2021100423229 dated 04/10/2021)
3. M/s Side car ( a unit of barkeepers LLP), Plot No M-29, M- Block Market, GK-2, New Delhi-110048

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	Side Car Restaurant at 1 <sup>st</sup> & 2 <sup>nd</sup> Floor, M-29, M Block Market, GK-2, New Delhi-110048		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, ground, plus 02 upper floors (restaurant running at 1 <sup>st</sup> & 2 <sup>nd</sup> floor only)		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Approval of FPW at N/1		
7	Date of Inspection	05/10/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Kuldeep (Manger)		
10	Year of construction	1983 & 2009		
11	Applicant letter No.	MHA Portal ID 2021100423229 dated 04/10/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Circular 2005 requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Restaurant N/A N/A	6 mtr N/A N/A	MR N/A N/A
2	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basement floor</li> </ul>	02 N/A	02 N/A	MR N/A
	<b>b. Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basement floor</li> </ul>	1.50 & 1.20 m N/A	Provided N/A	MR N/A
	<b>c. Protection of exits</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	01 No	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	2 Exits	2m & 1.25m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	N/A 12 ACPH	N/A Provided in kitchen	N/A MR
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	08 Nos ISI marked	08 Nos. ABC-04, W.CO <sub>2</sub> -02 Provided	MR MR MR
6	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	Required 30m 5mm	1st & 2 <sup>nd</sup> floor Provided Provided	MR MR MR
7	<b>Automatic Fire Detection and Alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	N/A	N/A

	<ul style="list-style-type: none"> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	NA	N/A	N/A
		NA	N/A	N/A
		NA	N/A	N/A
		NA	N/A	N/A
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Ground floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	Required	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	Required	01	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	01	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>2. Hose box.</li> </ul>	N/A	NA	N/A
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting / Manual Stopping.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Access to pump house</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 & 225 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	5,000 Ltrs	10,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided (DG Set)	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location</li> </ul>	N/A	N/A	N/A
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel.</li> </ul>	N/A	NA	N/A


	<ul style="list-style-type: none"> <li>Flow Switch Panel.</li> <li>PA system Panel.</li> <li>Battery backup</li> <li>Building floor plan</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	N/A	N/A	N/A

The management has constructed a safe passage/ corridor passage having width of 1.5m through kitchen area to access the rear side staircase/ exit.

The Fire protection systems provided in the building were tested/ checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name : Sh. Rajesh Kumar  
 Designation: ADO (BCP)

DO (South)

*Imp*  
*07/10/21*

DFO (S2)

*dh*  
*6/10*

*CFO. (on a P. D. off)*

*Director*

*7/10/21*  
*FIPS*

*Amu b/n*

As approved, f.t. letter is put up for