

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/BNQT./2021/SZ/ 486

Dated: 6/10/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s S & S Pioneer Corp, Plot No.- A-29 & A-30, Mayapuri Industrial Area Phase-II, New Delhi-110064 comprised of ground floor only having two halls, was issued FSC by this department vide letter no. F6/DFS/MS/BNQT./2018/SZ/2370 dated 22/10/2018 owned/occupied by M/s S & S Pioneer Corp was re-inspected by the officers concerned of this department on 24/09/2021 in the presence of Sh. Javed (Manager) and found that the banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on..... 6/10/2021 at New Delhi.



(SUNIL CHAWDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Manager,
M/s S & S Pioneer Corp,
Plot No.- A-29 & A-30 Mayapuri Industrial Area,
Phase-II, New Delhi-110064
2. The Dy. Health Officer,
S.D.M.C. Public Health Department, West Zone,
Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : M/s S & S Pioneer Corp, Plot No.- A29, A -30, Mayapuri Industrial Area Phase-II, New Delhi-110064,
2. Building comprised of : Ground floor only (2 Nos. Banquet Hall)
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/BNQT./2018/SZ/2370 dated 22/10/2018
6. Fire Safety directives letter No : N/A
7. Date of inspection : 24/09/2021
8. Name of Inspecting Officers : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Javed (Manager)
10. Year of Construction : 2014
11. Applicant's letter No. : 2021090320045 dated 08/09/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 m 4.5 m N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			Ground floor only
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	N/A N/A	N/A N/A	N/A N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	2.0 m	4.0 m	MR
	f. Door Size	2.0 m	2.75 m (04 no.'s in each hall)	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground floor 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	15 No.'s ABC/CO ₂ ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Three 30 m 5 mm	Provided Provided Provided	MR MR MR

Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	Provided	MR
		N/A	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	Required	Provided	MR
		Two	Provided	MR
		Two	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Two	N/A
		N/A	Two	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		900 LPM	900 & 180 LPM provided	MR
		30 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
		15000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/BNQT./2018/SZ/2370 dated 22/10/2018 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav
 Signature of Inspecting Officer ^{27/9/2021}

Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

D.O. (South West)

R. K. Yadav
 30/09/2021
 Dy CRO (S2)

h F.T.

A.O.O (R.K.)

F.T letter is put up for signature please

Dy CRO (S2)

F.T.

R. K. Yadav
 4/10/2021

A.O.O (S.K.B.)
 H.S. [Signature]