

L-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 281

Dated: 8/10/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s KFC Restaurant**, (A unit of Sapphire Foods India Pvt. Ltd) at F-4, Main Road, Kalkaji New Delhi 110019 comprised of Basement, Stilt, Ground plus three upper floor only (restaurant is running at **ground & first floor** of the building) was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/SZ/2018/2216 Dated 01/10/2018. The restaurant premise was re-inspected by the officer concerned of this department on 30/09/2021 in the presence of Sh. Sufian (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant as above with effect from 8/10/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 8/10/2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID No. 2021091221117 dated 12/09/2021)
3. M/s KFC Restaurant, (A unit of Sapphire Foods India Pvt. Ltd) at F-4, Main Road, Kalkaji New Delhi 110019

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

M/13

INSPECTION REPORT

1	Name & Address of the Building	M/s KFC Restaurant, (A unit of Sapphire Foods India Pvt. Ltd) at F-4, Main Road, Kalkaji New Delhi 110019		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, Stilt, ground, plus 03 upper floors (restaurant running at ground & First floor only)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2018/2216 dated 01/10/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	30/09/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sufian (Manager)		
10	Year of construction	2013		
11	Applicant letter No.	Online Id 2021091221117 dated 12/09/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restaurant N/A N/A	09 mtr N/A N/A	MR N/A N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	02 Nos N/A	02 Nos N/A	MR N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	1.50 m N/A	1.50m & 1.25 m N/A	MR (old case) N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircase to terrace	01 Nos	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Exit	2 mtr & 1.50 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	N/A 12 ACPH	N/A Provided in kitchen	N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	06 Nos ISI marked	06 Nos. ABC-04, W.CO ₂ -02 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	01 30m 5mm	Provided Provided Provided	MR MR MR

25/18

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground floor	NA	NA	NA
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	01	Provided	MR
	• Hose box.	01	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	NA	N/A
	• 2. Hose box.	N/A	NA	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	NA	N/A
	➤ Head of main pump.	N/A	NA	N/A
	➤ Number of main pumps.	N/A	NA	N/A
	➤ Jockey Pump output.	N/A	NA	N/A
	➤ Jockey Pump head.	N/A	NA	N/A
	➤ Standby Pump output.	N/A	NA	N/A
	➤ Standby Pump head.	N/A	NA	N/A
	➤ Auto Starting / Manual Stopping.	N/A	NA	N/A
	➤ Access to pump house	N/A	NA	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40 m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 Ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
		Required	Provided (DG Set)	MR
17	Standby Power Supply			
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room.			

2/19

	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	NA	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2018/2216 dated 01/10/2018, renewal under rule 35 (6) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

M.S.
01/10/2021

Signature of the Inspecting Officer
Name : Sh. Rajesh Kumar
Designation: ADO (BCP)

~~DO (South)~~

R.K.P.
01/10/2021

F.T

~~DeFO(SZ)~~

[Signature]

~~M.S. cell~~

As apporved, F.T. letter is put up for your signature P1

M.S.
8/11/2021

~~DeFO/SZ~~

[Signature]
8/10

M.S. cell