

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001


No F 6/DFS/MS/2021/School/WZ/ 820

Dated: 6/10/2021

FIRE SAFETY CERTIFICATE

Certified that the **Dev Convent School, Kh. No.80, Gali No.11, Railway Raod, Samaypur, Delhi-110042**, comprised of **Ground + One upper floor** owned/occupied by **Dev Convent School** was granted FSC by this department vide letter **No. F.6/DFS/MS/2018/1315** dated **05.06.2018**. The premises was re-inspected by the officer concerned of this department on **01.09.2021** in the presence of **Sh. Dev Pal (President)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ...6.10.21... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on6/10/21..... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The President, Dev Convent School, Kh. No.80, Gali No.11, Railway Raod, Samaypur, Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

Name & address of the building : Dev Convent School, Kh. No.80, Gali No.11, Railway Road, Samaypur, Delhi-110042.

Type of Occupancy : Educational

3. Type of Case : Renewal (Ground + One upper floor)

4. Details of Previous NOC : E.6 DFS/MS 2018/1315 dated 05.06.2018

5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011

6. Date of inspection : 01.09.2021

7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)

8. Name and designation of officers
From the building side : Sh. Dev Pal (President)

9. Year of Construction : 2007

10. Applicant's letter No. : OD No.1400 dated 02.07.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Educational Cir. dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	08nos.	08nos.	MR
	• Types	ABC/CO2	ABC-08	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

N116

Special Fire Protection

	<ul style="list-style-type: none"> • Hoisters' Location 	NA	NA	NA	NA
8.	MOEFA	NA	NA	NA	NA
9.	Public Address System	NA	NA	NA	NA
10.	Automatic Sprinkler System <ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling 	NA	NA	NA	NA
11.	Internal Hydrants <ul style="list-style-type: none"> • Size of riser down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA	NA
12.	Yard Hydrants <ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA	NA
13.	Pumping Arrangements <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/Manual Stopping ➢ Pump House Access • Terrace level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Power Supply ➢ Auto Starting of pump 	NA	NA	NA	NA
14.	Captive Water Storage for fire fighting <ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➢ Draw-off connection ➢ Fire service inlet ➢ Access to tank • Overhead Tank capacity • Exit Signage. • Provision of Lifts. 	NA	NA	NA	NA
15.	Exit Signage.	NA	5,000ltr	Provided	NA
16.	Provision of Lifts.	NA	NA	NA	NA
17.	Standby power supply	NA	NA	NA	NA
18.	Refuge Area. <ul style="list-style-type: none"> ➢ Total Area ➢ Location 	NA	NA	NA	NA
19.	Fire Control Room <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA	NA

N/17

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/2018/1315 dated 05.06.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
17/9/21

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

DO (NW)

Ajay
30/09/2021
Dy LFO (W2)

[Signature]
4/10/2021

ADO Rohini

FT letter is put up for kind perusal and signature please.

Ajay
3/10/21

DFO (W2)
[Signature]
6/10/2021

MS/elf