

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/2021/ 493

Dated : 11/10/2021

FIRE SAFETY CERTIFICATE

Certified that the **National Sports Club of India** located at **Mathura Road, New Delhi** comprised of Ground + one upper floor, owned/occupied by **National Sports Club of India** was granted FSC by this department vide letter No.F6/DFS/MS/Club/2018/870 dated 01/05/2018. Now, the premises was re-inspected by the officers concerned of this department on 05/10/21 in the presence of **Sh. Naresh (Adm. Officer)** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Assembly Building, Sub-Division D-3** with effect from 11/10/21 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 11/10/2021 at New Delhi by.



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), 1st floor, Defence Colony Police Station, New Delhi. ID No 2021092622579 dated 28.09.21.
2. The Asstt. Commissioner (Excise), Office of Commissioner (Excise) GHCT, L & N Block, Vikas Bhawan, New Delhi.
3. The Manager/ Admin Officer, National Sports Club of India, Mathura Road, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : National Sports Club of India at Mathura Road, New Delhi, Ground + one upper floor
2. Type of occupancy : Group - D , Assembly occupancy
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/Club/2018/870 dated 01/05/18
5. Fire safety directives No. : NA
6. Date of inspection:- : 05/10/21
7. Name of the inspecting officer : Sh. Ravinder Singh , ADO (CC)
Sh. Rajinder Atwal , DO (CD)
8. Name & designation of officer : Sh. Naresh (Adm. Officer)
- From the building side : Old
9. Year of construction : 20210926225879 dated 28.09.21
10. Applicant's letter No : Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	16 Mtr.	MR
	2) Gate width	06 mtr.	06 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	03 No.	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	1 mtr.	1.10 mtr.	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	NA	NA	NA
	E. Width of corridor	1 Mtr.	1.25 Mtr.	MR
	F. Door size	1 Mtr.	1.5 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	NA	NA
	2) Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	24 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

	1) Total number of each floor	02 No.	02 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box each floor	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	05	05	MR
	2) Hose box per floor	05	05	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	900 LPM	900 LPM	MR
	b) Head of main pump	40 mtr.	45 mtr.	MR
	c) Number of main pump	01	02	MR
	d) Jockey pump out put	280	280	MR
	e) Jockey pump head	40 mtr.	45 mtr.	MR
	f) Stand by pump output (Diesel Pump)	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	900 & 180 lpm	N/A
	b) Head of pump	N/A	40 m	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltr.	50,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank	10,000 ltr.	10,000 ltr.	MR

	capacity			
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC, Co2			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/Club/2018/870 dated 01/05/2018, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

[Handwritten Signature]
6/11/21

Name:- Rajinder Atwal


Designation:-DO(CD)

Signature of the Inspecting Officer

[Handwritten Signature]
6/11/21

Name:- Ravinder Singh

Designation:- ADO (CC)



[Handwritten Signature] F.T.P.
[Handwritten Signature] 7/11/21

ADOC(CD) - 92

F.T. letter is put up for signature pl.

[Handwritten Signature]
[Handwritten Signature] 8/11/21

[Handwritten Signature]
8/11/21