

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2021/NDZ/ 492

Dated: 08-10-2021


FIRE SAFETY CERTIFICATE

Certified that the M/s Le-Paradise Banquet Hall at 341 6B-1, G.F., Kanti Nagar, Delhi-110051, comprised of lower ground, ground plus two upper floor (Banquet running on ground floor only) owned/occupied by M/s Le-Paradise Banquet was issued FSC for ground floor vide letter No. F.6/DFS/MS/Banquet/2014/NDZ/1525 dated 04/12/2014. The banquet have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 02/09/2021 in the presence of Sh. Vijay Kumar Goyal (Owner) and that the premises is fit for occupancy class "D" 'Assembly (Banquet Hall)' for ground floor only with effect from 08-10-2021.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf..

Issued on 08-10-2021. at New Delhi by


5/10/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



1. The Commissioner :- To ensure occupancy in the building as detailed above
EDMC, Headquarters,
419, Udyog Sadan, Patparganj Industrial Area,
New Delhi-110092
2. The Dy. Health Officer,
EDMC, Health Department
Shahdara (South) Zone, Karkardooma,
Shahdara, Delhi
3. Sh. Vijay Kumar Goyal, Owner
M/s Le-Paradise Banquet Hall,
341 6B-1, G.F., Kanti Nagar,
Delhi-110051

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/23

INSPECTION REPORT

- | | |
|---|--|
| 1. Name & address of the building | : Le Paradise Banquet Hall at 341/6B-1, Kanti Nagar Delhi. |
| 2. Building is comprised of | : LG+G+2, Banquet running on ground floor |
| 3. Type of Occupancy | : Assembly Building |
| 4. Type of Case | : Renewal |
| 5. Details of Previous NOC letter | : F.6/DFS/MS/Banquet/2014/NDZ/1525 dated 04/12/14 |
| 6. Fire Safety direction letter No | : NBC Part-IV |
| 7. Date of Inspection | : 02/09/2021 |
| 8. Name of the Inspecting officers | : ADO Nagender Singh |
| 9. Name and designation of Officer from the building side | : Sh. Vijay Kumar Goyal (Owner) |
| 10. Year of Construction | : 2010 |
| 11. Applicant's email ID | : aakshay34@gmail.com dated- 23/08/2021 |

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m N/A N/A	15 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	02 nos. N/A	03 nos. N/A.	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	2 m & 1.5m N/A	2 m , 1.5 m & 1 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	N/A	N/A	MR
	f. Door Size	02 m	2 nos. of 2 m, 1 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A Required	N/A Provided	N/A M/R
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. ABC /CO ₂ ISI marked	06 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	1 no.	MR
	• Hose box	N/A	1 no.	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting/manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 LPM	Provided	MR
	• Head of the pump	40m	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltr.	20,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

N/25

		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

Kindly peruse the request received from owner/occupier of Le Paradise to grant Fire Safety Certificate for ground floor only as per past FSC (C/56) & 1st /other floors will not be used for any other purpose until the shortcomings already communicated vide letter No.F.6/DFS/MS/BNQT/2021/580 dated 11/03/2021 are rectified.

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010 for ground floor only.

(Signature)
16/9/21
(Nagender Singh)
ADO (Shahdara)

Dy. CEO (NDZ)

F.R. pl.

(Signature)
24/9/21

Admission FT letter is placed for signatures please

Dy. CEO (NDZ)

(Signature)
5/10/21

(Signature)
30/9/21