

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**


No. F.6/DFS/MS/Audi./2021/SZ/ 504

Dated: 17/10 /2021


**FIRE SAFETY CERTIFICATE**

Certified that M/s **Jawaharlal Auditorium** located at AIIMS Complex, Ansari Nagar, New Delhi-110029, comprised of **Basement, Ground plus Balcony** was granted FSC by this department vide letter No. F.6/DFS/MS/2017/SZ/107 dated 24/01/2017. The premises was re-inspected by the officer concerned of this department on 05/10/2021 in the presence of Mr. Deepak Kumar, Dy. CSO & Mr. Ashok Sharma (Fire Officer) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Group-D**" (Auditorium) with effect from 17/10 /2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/10 /2021 at New Delhi by



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service



Copy to: -

1. Mr. Deepak Kumar (Dy. CSO), AIIMS, Ansari Nagar, New Delhi-110029
2. The Jt. Commissioner of Police (Lic.), 1<sup>st</sup> Floor, P.S. Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	<b>Jawaharlal Auditorium, AIIMS Complex,</b> Ansari Nagar, New Delhi - 110029		
2	Type of Occupancy	Assembly Building "Group-D"		
3	Building Comprised of	Basement, Ground plus Balcony Floor. Total - 930 Seats. GF - 566 and Balcony - 354 Seats		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/SZ/2017/107 dated 24/01/2017		
6	Fire Safety Directives Letter No	F6/DFS/MS/81/738 Dated 20/11/1981		
7	Date of Inspection	05/10/2020		
8	Name of the Inspecting Officers	DO (SD)		
9	Name & Designation of Officers from the building side	Mr. Deepak Kumar (Dy. CSO), AIIMS and Mr. Ashok Sharma (Fire Officer)		
10	Year of construction	Prior to 1983		
11	Applicant letter No.	Outdoor Diary No. 2670 Dated 15/09/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Required	12m	MR
	• Gate width	Required	6m	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	➤ Upper floors	4 Nos	4 Nos	MR
	➤ Basement floor	1 No	1 No	MR (old case)
	<b>b. Width of Staircase</b>			
	➤ Upper floors	Required	1.55m (one) and 0.83m (three)	MR (old case)
	➤ Basement floor	Required	0.83m	MR (old case)
	<b>c. Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircase to terrace</b>	One	Provided	MR
	<b>e. Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door size</b>	Required	6 Exits at GF - 1.3m (each) 2 Exits at FF - 1.3m (each)	MR (old case)
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	Required	Provided	MR
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30ACPH	Exhaust Fans provided	MR
	• Upper floors	12 ACPH	Exhaust Fans provided	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	14 Nos	20 Nos	MR
	• Types	ABC/CO <sub>2</sub> /W.CO <sub>2</sub>	Provided	MR
	• ISI Marking	ISI Marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	GF-02 & FF-01	GF-02 & FF-01	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Required	Beam Detector	MR
		Ground floor	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		All Areas	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	Required	150mm	MR
		GF-02 & FF-01	Provided	MR
		GF-02 & FF-01	Provided	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	02 Nos	Provided	MR
		02 Nos	Provided	MR
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	1620 LPM	1620 LPM	MR
		70m	70m	MR
		One	One	MR
		2 x 280 LPM	2 x 280 LPM	MR
		70 (each)	70 (each)	MR
		1620 LPM	1620 LPM	MR
		70m	70m	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	<b>Captive water storage for Fire Fighting.</b>	Common for PC Teaching Block & Auditorium		
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	50,000 Ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA

19.	<b>Fire Control Room.</b>	Provided at ground floor			
		• Detector System Panel.	Required	Provided	MR
		• Flow Switch Panel.	-NA-	-NA-	-NA-
		• PA system Panel.	Required	Provided	MR
		• Battery backup	Required	Provided	MR
	• Building floor plan	-NA-	-NA-	-NA-	
20.	<b>Special Fire Protection System for the Protection of special Risk, if any:</b>	HT, LT & Transformer are provided with ABC & CO <sub>2</sub> type fire extinguishers		MR	

The Fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the fire safety certificate issued vide letter No. F6/DFS/MS/2017/SZ/107 dated 24/01/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*S.K. Dua*  
08/10/21

Signature of the Inspecting Officer  
Name : S.K. Dua  
Designation: DO (SD)

DCFO (SZ)

*F.T.*  
*S.K. Dua*  
8/10

*DO S.D.*

*F.T. letter is put up for sig. pl.*

*S.K. Dua*  
11/10/21

*DCFO (SZ)*  
*[Signature]*

*M.S. all*