

C/15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F.6/DFS/MS/2021/School/WZ/ 854

Dated: 13/10/2021

FIRE SAFETY CERTIFICATE

Certified that the **M C Primary Co-ed School, Nizampur, Delhi-81**, comprised of **Ground + One upper floor** owned/occupied by **M C Primary Co-ed School** was granted FSC by this department vide letter no. **F.6/DFS/MS/2017/School/WZ/1076 dated 24.07.2017**. The premises was re-inspected by the officer concerned of this department on **17.09.2021** in the presence of **Smt. Suman Lata** (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from **13/10/2021** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **13/10/2021** at New Delhi

JG/10/2021
(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Principal, M C Primary Co-ed School, Nizampur, Delhi-81.
2. The Commissioner, NDMC, Sector-5, Rohini, New Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/9

INSPECTION REPORT

**Single block
Ground + One upper floor**


1. Name & address of the building : M C Primary Co-ed School, Nizampur, Delhi-81
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2017/School/WZ/1076 dated 24.07.2017
5. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
6. Date of inspection : 17.09.2021
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Smt. Suman Lata (Principal)
9. Year of Construction : 2002
10. Applicant's letter No. : Online e-mail dated 30.03.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible N/A 	<ul style="list-style-type: none"> Accessible 4.0 mtr N/A 	<ul style="list-style-type: none"> MR MR (Old case) N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 01 N/A 	<ul style="list-style-type: none"> 01 N/A 	<ul style="list-style-type: none"> MR N/A
	b. Width of staircases	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 1.5m N/A 	<ul style="list-style-type: none"> 1.5m N/A 	<ul style="list-style-type: none"> MR N/A
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 04 ABC ABC/Co2 ISI marked 	<ul style="list-style-type: none"> 06 ABC-6 Yes 	<ul style="list-style-type: none"> MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> NA 	<ul style="list-style-type: none"> N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A


N/11


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/2017/School/WZ/1076 dated 24.07.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

~~DO (NW)~~


30/09/2021
~~Dy CPO (WZ)~~



4/10/2021

~~ADO Rohini~~

FT letter is put up for kind perusal and signature please.


4/10/21


~~Dy CPO (WZ)~~


6/10/2021


~~ADO Rohini~~

Sir,

rest two copies of FT may kindly also be signed.


12/10/21

~~Dy CPO (WZ)~~


17/10/2021

not cc

4
5
6
7