

C/30
=124

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001


No F 6/DFS/MS/2021/School/WZ/ 855

Dated: 13 /10 /2021

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya/ Bal Vidyalaya, Sec-16, Rohini, Delhi-85, comprised of 04 blocks, One block- Ground floor & 03 blocks- Ground + One upper floors owned/occupied by Govt. Sarvodaya Kanya/ Bal Vidyalaya, was granted FSC by this department vide letter No. F.6/DFS/MS/School/2018/WZ/667 dated 12.04.2018. The premises was re-inspected by the officer concerned of this department on 02.09.2021 in the presence of Smt. Asha Sharma (Head of School) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ...13/10/2021 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...13/10/2021 at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Govt. Sarvodaya Kanya/ Bal Vidyalaya, Sec-16, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

2/16

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Knaya/ Bal Vidyalaya, Sec-16, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (04 Blk, One Blk-Gr. floor & 03 Blk-Gr. + 1 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/School/2018/WZ/667 dated 12.04.2018
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
6. Date of inspection : 02.09.2011
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Smt. Asha Sharma (Head of School)
9. Year of Construction : 1995 & 2005
10. Applicant's letter No. : Online e-mail dated 05.08.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.0m	MR(old case)
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	Block-A-1.5 Block-C-1.4m x 2 Block-D-1.5m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	17nos.	38nos.	MR
	• Types	ABC/CO2	ABC-38	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

21

015

H/17

8.	MOEFA	NA	NA	NA	• Hooters' Location
9.	Public Address System	NA	NA	NA	
10.	Automatic Sprinkler System	NA	NA	NA	• Basement
		NA	NA	NA	• Ground & Upper Floors
		NA	NA	NA	• Sprinkler above false ceiling
11.	Internal Hydrants	NA	NA	NA	• Size of riser/down-comer
		NA	NA	NA	• Number of hydrants per floor
12.	Yard Hydrants	NA	NA	NA	• Hose Box
		NA	NA	NA	• Total number of hydrants
13.	Pumping Arrangements	NA	NA	NA	• Ground Level
		NA	NA	NA	• Discharge of main Pump
14.	Captive Water Storage for fire fighting	NA	NA	NA	• Head of Main pump
		NA	NA	NA	• Number of main pumps
		NA	NA	NA	• Jockey Pump out put
		NA	NA	NA	• Jockey pump head
		NA	NA	NA	• Standby Pump out put
		NA	NA	NA	• Standby Pump Head
		NA	NA	NA	• Auto Starting/Manual Stopping
		NA	NA	NA	• Pump House Access
		NA	NA	NA	• Terrace level
		NA	NA	NA	• Discharge of pump
		NA	NA	NA	• Head of the pump
		NA	NA	NA	• Power Supply
		NA	NA	NA	• Auto Starting of pump
		15.	Exit Signage.	NA	NA
NA	NA			NA	• Draw-off connection
NA	NA			NA	• Fire service inlet
NA	NA			NA	• Access to tank
NA	NA			NA	• Overhead Tank capacity
NA	NA			NA	
16.	Provision of Lifts.	NA	NA	NA	• Pressurization of Lift Shaft
		NA	NA	NA	• Pressurization of Lift lobby
		NA	NA	NA	• Communication In lift Car
		NA	NA	NA	• Fireman's Grounding Switch
		NA	NA	NA	• Lift Signage
		NA	NA	NA	
17.	Standby power supply	NA	NA	NA	
		NA	NA	NA	
18.	Refuge Area.	NA	NA	NA	• Total Area
		NA	NA	NA	• Location
		NA	NA	NA	
19.	Fire Control Room	NA	NA	NA	• Detector System Panel
		NA	NA	NA	• Flow Switch Panel
		NA	NA	NA	• PA System Panel
		NA	NA	NA	• Battery backup
		NA	NA	NA	• Building Floor Plans

Spec P

N/18

NA	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
NA		The fire protection systems provided in the building were test checked and found functional at the time of inspection.		
NA		Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/2018/WZ/667 dated 12.04.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.		

Ajay
17/9/21

Signature of the Inspecting Officer
Name: Ajay Kumar Sharma
Designation: ADO(Rohini)

~~DO (NW)~~ Pl. make corrections

Ajay
30/09/2021

~~ADO (R)~~

Corrected DFO is put up for kind perusal and signature please.

Ajay
15/10/21

~~DFO (W2)~~

Ajay
05/10/2021

~~DFO (W2)~~

Ajay
6/10/2021

FT letter is put up for kind perusal and signature please

~~ADO Rohini~~

Ajay
12/10/21

~~DFO (W2)~~

~~ADO (W2)~~