

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/EH/2021/290

Dated : 14.10.2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M/S ANDHRA CANTEEN ( Unit of Mahatta and Company )** located at **M 58-59, ground, mezzanine & first floor, Connaught Place, New Delhi**, comprised of **Ground + Mezzanine + 02 Upper floor but restaurant running at Ground , Mezzanine and first only**. The FSC was earlier granted to the said premises ( **Surahi Restaurant** ) by this department vide letter No. **F6/DFS/MS/EH/2017/NDZ/1394** dated **21.09.2017**. Now, The premises was re-inspected by the officer concerned of this department on **12/10/21** in the presence of **Mr. Duggal** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building- Group D, Restaurant running at Ground , Mezzanine & First floor only** with effect from **14/10/2021** for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 14/10/2021 at New Delhi by.

  
**(Dr. S.K. Tomar )**  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. The Medical Officer of Health,, Health Department, Palika Kendra, New Delhi.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID NO. 2021092622567 dated 26.09.21
3. The Manager, ANDHRA CANTEEN ( Unit of Mahatta and Company ) located at M 58-59 , ground , mezzanine & first floor , Outer Circle ,Connaught Place, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

21/14  
INSPECTION REPORT

- |   |  |
|---|--|
| 1. Name & address of the building                         | M/S ANDHRA CANTEEN ( Unit of Mehta and Company ) located at M 58-59 , ground , mezzanine & first floor ,Connaught Place, New Delhi |
| 2. Type of occupancy:-                                    | Gr. + Mez. + 02 upper floor Assembly Building Group-D , Restaurant at Gr., Mezzanine and first floor only                          |
| 3. Type of case:-   | Renewal  |
| 4. Details of previous FSC:-                              | F6/DFS/MS/EH/2017/NDZ/1394dated 21/09/17   |
| 5. Fire safety directives No.-                            | N/A  |
| 6. Date of inspection:-                                   | 12/09/21   |
| 7. Name of the inspecting officer:-                       | Sh. Ravinder Singh (ADO/CC)<br>Sh. Rajinder Atwal ( DO /CD)  |
| 8. Name & designation of officer from the building side:- | Mr. Duggal<br>Old Heritage Bldg.   |
| 9. Year of construction:-                                 | ID NO. 2021092622567 dated 26.09.21  |
| 10. Applicant's letter No:-                               |  |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	6 mtr	15 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	1.25 mtr & .80 mtr	1.25 mtr & .80 mtr	MR ( old case)
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.50 mtr	2.0mtr	N/A
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural/exhaust fan	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	06 Nos.	06Nos.	MR



	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors( smoke )	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100mm	100mm	MR
	2) Number of hydrants per floor	01 nos	01 Nos	MR
	3) Hose box	01 nos	01 nos	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A

MR  
MR  
MR  
MR  
MF

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity (14000 terrace + 6000 ground floor)	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued to said premises vide letter no. F6/DFS/MS/EH/2017/NDZ/1394 dated 21/09/17, renewal under rule 35 of the Delhi Fire Service Rules 2010, is recommended for approval.

Signature of the Inspecting Officer


Signature of the Inspecting Officer

*Real* 19/10/21

*[Signature]* 21/10/21

Name :- Sh. Rajinder Atwal  
Designation:- DO (CD)

Name :- Ravinder Singh  
Designation :- ADO (CC)



*[Signature]* 13/10/21

*[Signature]* 13/10/21

*[Signature]*

As approved by 'Patrap' for Renew

Perused and signed true Please.

*[Signature]* 13/10/21

*[Signature]*

*[Signature]* 13/10/21