

C/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 849

Dated: 13/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Arwachin Bharti Bhawan Sr. Sec. School at C-Block, Vivek Vihar, Delhi-110095 comprised of two blocks the first block basement, ground plus two upper floors & second block ground plus three upper floors owned/occupied by Arwachin Bharti Bhawan Sr. Sec. School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1648 dated 16/07/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 30/09/2021 in the presence of Mr. Ravi Chauhan, Caretaker of the school and that the school building is fit for occupancy class "B" 'Educational Building' with effect from 13/10/2021. for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on 13/10/2021 at New Delhi by



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

o/c

To,  
The Principal,  
Arwachin Bharti Bhawan Sr. Sec. School,  
C-Block, Vivek Vihar, Delhi-110095

Copy to:-

1. The Commissioner,  
EDMC, Headquarters,  
419, Udyog Sadan, Patparganj Industrial Area,  
New Delhi-110092
2. The Dy. Director of Education,  
D-Block, Anand Vihar, Delhi

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL/National Building Code.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Arwachin Bharti Bhawan Sr. Sec. School, Vivek Vihar, Delhi-110095
2. Building is comprised of : Two Blocks i.e. First block B+G+2 & Second block G+3
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2018/NDZ/1648 dated- 16/07/2018
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 30/09/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Mr. Ravi Chauhan, Caretaker
10. Year of Construction : 2005
11. Applicant's Email ID : arwachinschool@gmail.com dated 23/07/2021


Sr. No	Minimum Standards on fire prevention and fire safety U/R33	NBC-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	6 m	20 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	4 nos.	4 nos.	MR
	• 1 <sup>st</sup> Block B+G+2	2 nos.	2 nos.	MR
	• 2 <sup>nd</sup> Block G+3	2 nos.	2 nos.	MR
	• Basement in 1 <sup>st</sup> block only	2 nos.	2 nos.	MR
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.5 m	MR
	• 1 <sup>st</sup> Block B+G+2	1.5 m	1.5 m	MR
	• 2 <sup>nd</sup> Block G+3	1.5 m	1.5 m	MR
	• Basement	1.5 m	1.5 m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1 m	1.2 m	MR
03	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System			
	• Basement	Required	Provided	MR
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers			
	• Total numbers	40 nos.	40 nos.	MR
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR



N/20

		Required	Provided	MR
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under the NBC Part-IV, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.

  
(Nagender Singh)  
ADO (Shahdara)

Dy. CFO (NDZ)

F.R.p1.

  
8/10/21




ADORSHANI

FT letter is placed for signatures please

Dy CFO (NDZ)

  
11/10/21

  
11/10

ms