

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No F.6/DFS/MS/2021/School/WZ/ 850

Dated: 13/10/2021

FIRE SAFETY CERTIFICATE

Certified that Deep Chand Public School, Begumpur, (Opp. Rohini Sec-22, Delhi-110085) comprised of Ground + One upper floor owned/occupied by Deep Chand Public School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/School/2016/WZ/74 Dated 08.01.2016. The premises was re-inspected by the officer from this department on dated 28.09.2021 in the presence of Sh. Anil Yadav (Chairman) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 13/10/2021 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 13/10/2021 at New Delhi by


13/10/21
Dhrampal Bhardwaj;
Dy.Chief Fire Officer
Tel:-01123414250

Copy to:

1. The Principal, Deep Chand Public School, Begumpur, (Opp. Rohini Sec-22, Delhi-110085).
2. The Director of Education, Old Secretariat, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available or WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT**Gr. + One upper floor**

1. Name & address of the building : Deep Chand Public School, Begumpur, (Opp. Rohini Sec-22)
Delhi-110085
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2016/WZ/74 Dated 08.01.2016
5. Fire Safety directives letter No : Dir of Edu, Cir 01/03/2011
6. Date of inspection : 28.09.2021
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
from the building side : Sh. Anil Yadav (Chairman)
9. Year of Construction : 2009
10. Applicant's letter No. : OD No.2382 dated 27.08.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr	0.85 mtr up to 1 st floor & 1.40 mtr up to roof	MR
	• Basements	NA	NA	NA
	c. Protection of exits	—	—	—
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	1.00 mtr	1.00 mtr	MR
3	Compartmentation.	—	—	—
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	07 ABC	08	MR
	• Types	ISI marked	ABC-8	MR
	• IS marking		Yes	MR
6	First-Aid Hose Reels.			


	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 LPM 40 M NA NA	NA NA NA NA NA NA NA NA NA NA Provided Provided NA NA	NA NA NA NA NA NA NA NA NA NA MR MR NA NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 5,000 ltr	NA NA NA NA Provided	NA NA NA NA MR NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	NA NA	NA NA	NA NA

24/4


	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/School/2016/WZ/74 Dated 08.01.2016 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.



309121


Signature of the Inspecting Officer
Name: Ajay Kumar Sharma
Designation: ADC (Retired)

~~DC (WZ)~~  04/10/2021

By ~~DC (WZ)~~ to ~~Post~~ of document
D-What about adjacent block.

 14/10/2021

~~DC (WZ)~~  Sir,
- Applicant submitted photograph of second floor for not in use.
- Applicant requested for renewal of existing license only.
Resubmitted license.

 7/10/21