

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/

499

Dated: 13/10/2021

FIRE SAFETY CERTIFICATE

Certified that the **Metro Station, DMRC** located at Metro station, Sector – 11, Dwarka. New Delhi, comprised of Ground, + 01 Upper Floor was issued FSC vide letter no. F6/DFS/MS/2006/SZ/3378 dated 17-11-2006. The premises was re inspected by the officer concerned of this department on 06-10-2021 in the presence of Sh. Sudhanshu Mudgal (Fire Inspector) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D – 7 with effect from ..13/10/2021.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on13/10/2021..... at New Delhi by.

(Sunil Chaudhary)

Dy. Chief Fire Officer.
Delhi Fire Service

Copy to:

Sh. Sudhanshu Mudgal, Metro station, Sector – 11, Dwarka. New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: : Metro station, Sector – 11, Dwarka. New Delhi.
2. Type of Occupancy : Assembly (D – 7) (G+1)
3. Type of Case : Renewal (Ground + One Upper floor)
4. Details of previous NOC : F6/DFS/MS/2006/SZ/3378 dated 17-11-2006
5. Fire Safety directives Letter No. : As per NBC Code of India
6. Date of inspection : 06-10-2021
7. Name of the Inspecting Officer : Udai Vir Singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Sudhanshu Mudgal (Fire Inspector)
9. Year of Construction : 2006
10. Applicant's letter No. : Email Dated 02/10/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3, N/4, N/5	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	12 mtr	MR
	• Gate width	NA	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	04 NOs.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	02 mtr	3.60 mtr	MR
		NA	NA	NA
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1 m	01 mtr & 2.10 m	MR(old Case)
	f. Door Size			
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	02 hrs	02 hrs	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	35 CO2 & WCO2 Required	35 Nos. CO2, WCO2 Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04 on each platform 45 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150mm 04 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	04 Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	All the pumps are connected with generator also 1800lpm 7 0m 1 180lpm 7 0m 1800lpm 7 0m Required Required NA NA NA NA	Provided Provided Provided Provided Provided Provided Provided Provided Provided NA NA NA NA	MR MR MR MR MR MR MR MR MR NA NA NA NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	50,000ltrs Required Required Required NA	Provided Provided Provided Provided NA	MR MR MR MR NA

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 gas flooding for ESS room	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2006/SZ/3378 dated 17-11-2006 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Uday Vir Singh*

Designation *AO/DW*

10/11/21

D/S/O

10/11/2021

Dy c/o (S2)

h

15.7.

A O/D (DWK)

bir AP letter is put up for sig 1/10

Dy c/o S2

12/10

10/11/21

10/11/21