

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F.6/DFS /MS/2021/WZ/ 506

Dated 17/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **N. N. Mall at Plot No-15, Manglam Place District Center, Sec- 03 Rohini, Delhi-110085**, comprised of **Double Basement +G+05upper floors** owned/ occupied by **N.N Mall** was granted Fire Safety Certificate by this department vide letter no. **F.6/MS/DFS/2005/1607 Dated 02.08.2005**. The premises was re-inspected by the officers concerned of this department on **01.10.2021** in the presence of **Sh. Harender (Mall Manager)** and found that the building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010. and premises is fit for **Class –“Mixed Mercantile”** with effect from 17/10/2021 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....17/10/2021..... at New Delhi by

  
(Atul Garg)  
Director

Tel;-0112341000

Copy to:-

1. Sh. Harender (Mall Manager), N. N. Mall at Plot No-15, Manglam Place District Center, Sec- 03 Rohini, Delhi-110085.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

## INSPECTION REPORT

1. Name & address of the building : N.N Mall at Plot No-15, Manglam Place District Center, Sec- 03 Rohini, Delhi-110085.
2. Type of Occupancy : Mixed Mercantile ( Double Basement +G+05upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/MS/DFS/2005/1607 Dated 02.08.2005
5. Fire Safety directives letter No : F.6/DFS/MS/HQ/BP/2003/1925 Dated: 25/08/2003
6. Date of inspection : 07.10.2021
7. Name of the Inspecting Officers : DO (NW) D.B. Mukherjee & ADO Rohini A.K.Sharma
8. Name and designation of officers from the building side : Sh. Harender (Mall Manager)
9. Year of Construction : 2003
10. Applicant's letter No. : Nil Dated: 19.07.2021

	Minimum Standards on fire prevention and fire safety U/R 33	BBL & NBC/Rule35(6) Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09m	09m	MR
	• Gate width	05m	Directly Accessible	MR
	• Width of internal road	Control elevation	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	04	05	MR
	b. Width of staircases			
	• Upper Floors	1.50m	Provided	MR
	• Basements	1.50m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR (Only in Basement) <i>OK</i>
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	05	05	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR (Only in Basement) <i>OK</i>
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust Fan	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			

	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	50nos	70nos	MR
		Wco2/DCP type	WCo-40, DCP type-30	MR
		Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02 at each floor	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30mm	30mm	NA
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	05mm	05mm	NA
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	GF	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Each floor	Provided	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	At strategic location	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150mm	150mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02	02	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Required	Provided	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul> </li> </ul>	2850 LPM	2850 LPM	MR
		60 m	60m	MR
		02	02	MR
		180 LPM	180 LPM	MR
		60 M	Provided	MR
		2850 LPM	2850 LPM	MR
		80 m	80 m	MR
		450 lpm x2	450 lpm x2	MR

02/24

14	➤ Head of the pump	40 Mtr	450 Mtr	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>Captive Water Storage for fire fighting.</b>				
14	• Underground tank capacity	2,00,000 ltrs	2,00,000 ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltr	30,000 ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
<b>16 Provision of Lifts.</b>				
16	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
<b>18 Refuge Area.</b>				
18	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
<b>19 Fire Control Room</b>				
19	• Detector System Panel	G.F	Provided	MR
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	NA	NA	NA
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA		NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection and Shortcoming issued vide this department letter no. .... dated ..... have been found rectified.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/MS/DFS/2005/1607 Dated 02.08.2005 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Office  
 Name: - D.B Mukherjee  
 Designation:- DOWW

Signature of the Inspecting Officer  
 Name: - Ajay Kumar Sharma  
 Designation:- ADO/Rohini