

E-61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2021/ School/ ND2/852

Dated: 13/10/2021

FIRE SAFETY CERTIFICATE

Certified that the R.M. Arya Girls Sr. Sec. School located at **Behind Madhya Pradesh Emporium, Baba Kharak Singh Marg, Raja Bazar, New Delhi** comprises of **Ground + 01 Upper floor only**, was earlier granted FSC by this department vide letter no. F6/DFS/MS/2018/School/NDZ/115 dated 19/01/2018. Now, the premises was re-inspected by the officer concerned of this department on 07-10-2021 in the presence of Smt. Kiran Talwar and found that the said school building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I** with effect from 13/10/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below:

Issued on 13/10/2021 at New Delhi by.


13/10/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, R.M. Arya Girls Sr. Sec. School at Behind Madhya Pradesh Emporium, Baba Kharak Singh Marg, Raja Bazar, New Delhi
2. Director of Education, Govt. of NCT, Delhi.

Condition for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

2118

INSPECTION REPORT

1. Name & address of the building:- R.M. Arya Girls Sr. Sec. School at Behind Madhya Pradesh Emporium, Baba Kharak Singh Marg, Raja Bazar, New Delhi
2. Type of occupancy:- Educational Group B-I, Gr.+01 Upper Floor
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/2018/School/NDZ/115 dated 19/01/2018.
5. Fire safety directives No.- N/A
6. Date of inspection:- 07/10/21
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Smt. Kiran Talwar
1945 Heritage
9. Year of construction:- 1945 Heritage
10. Applicant's letter No:- E-mail< raghumalaryagirlsschool@yahoo.co.in > dated 18.09.2021

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04 Nos.	04 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.0 mtr.	1.4 mtr. each, 2 Nos. up to terrace	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	15 Nos.	17 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			

9

2

	1) Total number of each floor	04	04	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	2) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	3) Terrace level			
	a) Discharge of pump	180 LPM	180 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

	a) Pressurization of lift shaft	N/A	N/A	N/A																			
	b) Pressurization of lift lobby	N/A	N/A	N/A																			
	c) Communication in lift car	N/A	N/A	N/A																			
	d) Fireman's switch	N/A	N/A	N/A																			
	e) Lift signage	N/A	N/A	N/A																			
17.	Stand by Power Supply	N/A	N/A	N/A																			
18.	Refuge Area	N/A	N/A	N/A																			
	Total area location	N/A	N/A	N/A																			
19.	Fire Control Room	N/A	N/A	N/A																			
	a) Detector system panel	N/A	N/A	N/A																			
	b) Flow switch panel	N/A	N/A </tr <tr> <td></td> <td>c) PA system panel</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td></td> <td>d) Battery backup</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td></td> <td>e) Building floor plan</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>20.</td> <td>Special Fire Protection System for Protection of special Risk, if any:</td> <td></td> <td></td> <td>N/A</td> </tr>		c) PA system panel	N/A	N/A	N/A		d) Battery backup	N/A	N/A	N/A		e) Building floor plan	N/A	N/A	N/A	20.	Special Fire Protection System for Protection of special Risk, if any:			N/A
	c) PA system panel	N/A	N/A	N/A																			
	d) Battery backup	N/A	N/A	N/A																			
	e) Building floor plan	N/A	N/A	N/A																			
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A																			

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Director Education Circular, the FSC issued vide letter No. . F6/DFS/MS/2018/School/NDZ/115 dated 19/01/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer



Name :- Ravinder Singh
Designation :- A.D.O. (CC)

DO (CD)




11/x/21

Dy. C.F.O. NDZ

F.P.P.I.

D.T. Gaur
12/11/21



As approved, it is part of forced license and system plan.

Dy. C.F.O. NDZ

D.T. Gaur
13/11/21

13/10/21