

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 512

Dated: 18/10/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s National Centre Building (Action for Autism) at Pocket-7 & 8, Jasola Vihar, New Delhi 110025** comprised of Basement, Ground plus three upper floors owned/ occupied by **National Centre of Autism Society** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/1457 Dt. 21/06/2018. The said premises was re-inspected by officer concerned of this department on 07/10/2021 in presence of Sh. Salini (HR & Admn.) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" Group "**B**" (Institute) as above with effect from 18/10/2021 for a period of **Five years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 18/10 2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, M/s National Centre Building (Action for Autism) ^{SW} at Pocket-7 & 8, Jasola Vihar, New Delhi 110025
2. The Dy. Director (L &A) Delhi Development Authority, Vikas Sadan, INA, New Delhi

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/10

INSPECTION REPORT

1	Name & Address of the Building	M/s National Centre Building (Action for Autism) at Pocket-7 & 8, Jasola Vihar, New Delhi 110025		
2	Type of Occupancy	Educational Group B		
3	Building Comprised of	Basement, Ground + Three Upper Floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/1457 Dt. 21/06/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2003/1955 Dated 28/08/2003		
7	Date of Inspection	07/10/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Salini (HR & Admn.)		
10	Year of construction	2006		
11	Applicant letter No.	Gmail Dated 26/09/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	12 mtr	MR
	• Gate width	Required	5 mtr	MR
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No's	02 No's	MR
	➤ Basement floor.	02 No's	02 No's	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	1.50 mtr each	MR
	➤ Basement floor	1.50 mtr	1.50 mtr each	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided in basement	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan Provided.	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	10 Nos	MR
	• Types	ABC / wco2	ABC / wco2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	NA	-NA-

N/11

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	NA	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	100 mm	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	01 No	MR
	<ul style="list-style-type: none"> Hose box. 	Required	01 No	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	1620 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of main pump. 	39 M	Provided	MR
	<ul style="list-style-type: none"> Number of main pumps. 	01	Provided	MR
	<ul style="list-style-type: none"> Jockey Pump output. 	180 LPM	Provided	MR
	<ul style="list-style-type: none"> Jockey Pump head. 	39 M	Provided	MR
	<ul style="list-style-type: none"> Standby Pump output. 	1620 LPM	Provided	MR
	<ul style="list-style-type: none"> Standby Pump head. 	40 M	Provided	MR
	<ul style="list-style-type: none"> Auto Starting / Manual Stopping. 	Required	Provided	MR
	<ul style="list-style-type: none"> Pump house access. 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	900 LPM	900 LPM	MR
	<ul style="list-style-type: none"> Head of pump. 	40 mtr	Provided	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	50,000 Ltrs	Provided	MR
	<ul style="list-style-type: none"> Draw-off connection. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire Service Inlet. 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's switch. 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow switch panel. 	-NA-	-NA-	-NA-

N/A

	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 1695 dated 27/08/2021

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/1457 Dt. 21/06/2018 renewal under rule 35 (6) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh. Rajesh Kumar
11/10/21

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

Sh. Rajesh Kumar
11/10/21

F.T.

DeFO (S2)

[Signature]
12/10

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

Sh. Rajesh Kumar
14/10/21

Sh. Rajesh Kumar
15/10/21

[Signature]
15/10

M.S. [Signature]