

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 521

Dated. 25/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that **Musical Fountain Complex, (Block-3), Netaji Nagar, New Delhi 110023** Comprised of **ground floor and seating in open to sky in premise** owned/Occupied by **M/s Applause Hospitality Services Pvt. Ltd.**, was issued fire safety certificate by this department vide letter no F6/DFS/MS/EH/2018/SZ/1666 dated 16/07/2018. The premise was re-inspected by the officer concerned of this department on 18/10/2021 in the presence of Sh. P.J Thareja (Owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the premise is fit for occupancy **Group "D" Assembly Building** with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 25 / 10 /2021 at New Delhi by



**(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER**

Copy to: -

1. M/s One Golden Mile at Musical Fountain, (Applause Hospitality Services Pvt. Ltd) Block-3, Netaji Nagar, New Delhi 110023.
2. Medical Officer of Health NDMC Health Department, Palika Kendra, New Delhi 110001

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

122

**INSPECTION REPORT**

1	Name & Address of the Building	Musical Fountain Complex, (Block-3) Netaji Nagar, New Delhi 110023.		
2	Type of Occupancy	Assembly building Group D		
3	Building comprised of	Ground floor with open to sky area in premise		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2018/SZ/1666 dated 16/07/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/2014/170 dated 16/06/2014		
7	Date of Inspection	18/10/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. P.J Thareja (Owner)		
10	Year of construction	2014		
11	Applicant letter No.	Gmail dated 13/10/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As per old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	• Road width	06 m	Provided	MR
	• Gate width	05 m	06 m	MR
	• Width of internal road	NA	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors	-NA-	N/A	N/A
	• Basement floor	-NA-	N/A	N/A
	<b>b. Width of Staircase</b>			
	• Upper floors	-NA-	N/A	N/A
	• Basement floor	-NA-	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	01	01	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	2 m x 3 Nos 1 m x 2 Nos	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	N/A	N/A
	• Sealing of electrical shafts.	-NA-	N/A	N/A
	• Fire rating of shaft door.	-NA-	N/A	N/A
	• Water curtain	-NA-	N/A	N/A
	• Fire dampers.	-NA-	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	-NA-	N/A	N/A
	• Upper floors	-NA-	N/A	N/A
5	<b>Fire Extinguishers.</b>			
	• Total numbers	Required 08	08 Nos	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooper's location	-NA-	-NA-	-NA-

8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	-NA-	-NA-	-NA-
10	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	NA	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	01	MR
	• Hose box.	Required	01	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➢ Discharge of main pump.	-NA-	-NA-	-NA-
	➢ Head of main pump.	-NA-	-NA-	-NA-
	➢ Number of main pumps.	-NA-	-NA-	-NA-
	➢ Jockey Pump output.	-NA-	-NA-	-NA-
	➢ Jockey Pump head.	-NA-	-NA-	-NA-
	➢ Standby Pump output.	-NA-	-NA-	-NA-
	➢ Standby Pump head.	-NA-	-NA-	-NA-
	➢ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➢ Pump House Access	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➢ Discharge of pump.	450 LPM	Provided	MR
	➢ Head of pump.	40 m	Provided	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➢ Draw-off connection.	-NA-	-NA-	-NA-
	➢ Fire Service Inlet.	Required	Provided	MR
	➢ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 Ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	<b>Fire Control Room.</b>			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	-NA-	-NA-	-NA-

2/24

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2018/SZ/1666 dated 16/07/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Alk*  
18/10/2021

Signature of the Inspecting Officer  
Name : Sh. Rajesh Kumar  
Designation: ADO (BCP)

~~DO (SD)~~

*Alk*  
21/10/21

DeFO (S2)

F.T.  
*Sh*  
22/10

~~ADO (BCP)~~

As approved, F.T. letter is put up for  
your signature pl

*Alk*  
25/10/2021

DeFO/S2 *Sh*

M.S. cell