

C-42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 883

Dated: 26/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Jose Marti Sarvodaya Vidyalaya, located at R. K Puram, Sector 12, New Delhi - 110022** comprised of Ground + Two Upper floors (Except Auditorium) owned / occupied by Directorate of Education, Govt. of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/2246 Dated 05/10/2018. The said premises was re-inspected by officer concerned of this department on 18/10/2021 in presence of Karuna Sree Kunumuri (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Services Rules 2010, and that the school building is fit for occupancy class "**Educational Building**" Group – B with effect from 26/10/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 26/10 2021 at New Delhi by



**(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)**



Copy to: -

1. The Principal Jose Marti Sarvodaya Vidyalaya, R. K Puram, Sector 12, New Delhi – 110022.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

### INSPECTION REPORT

|               |   |   |                         |                       |
|---------------|---|---|-------------------------|-----------------------|
| 1             | Name & Address of the Building  | Jose Marti Sarvodaya Vidyalaya, R. K Puram, Sector 12, New Delhi - 110022 |                         |                       |
| 2             | Type of Occupancy   | Educational Building "Group-B" (School)                                   |                         |                       |
| 3             | Building Comprised of   | Ground + 02 Upper Floors, Except Auditorium                               |                         |                       |
| 4             | Type of Case  | Renewal   |                         |                       |
| 5             | Details of Previous NOC   | F6/DFS/MS/School/2018/SZ/2246 Dated 05/10/2018                            |                         |                       |
| 6             | Fire Safety Directives Letter No  | Nil   |                         |                       |
| 7             | Date of Inspection  | 18/10/2021  |                         |                       |
| 8             | Name of the Inspecting Officers   | Sh. Rajesh Kumar ADO (BCP)  |                         |                       |
| 9             | Name & Designation of Officers from the building side                             | Karuna Sree Kunumuri (Principal)  |                         |                       |
| 10            | Year of construction  | 1982  |                         |                       |
| 11            | Applicant letter No.  | Letter no nil Dated 04/10/2021  |                         |                       |
| <b>S. No.</b> | <b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>                | <b>Old NOC Requirement</b>  | <b>Provided at Site</b> | <b>Remarks MR/NMR</b> |
| 1             | <b>Access to Building.</b>  |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>• Road width</li> </ul>                    | 06 mtr  | 12 mtr                  | MR                    |
|               | <ul style="list-style-type: none"> <li>• Gate width</li> </ul>                    | Required  | 5 mtr                   | MR                    |
|               | <ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>        | -NA-  | -NA-                    | -NA-                  |
| 2             | <b>Number, width, type &amp; arrangement of exits.</b>                            |   |                         |                       |
|               | <b>a) Number of Staircase</b>   |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>➤ Upper floors.</li> </ul>                 | 02 Nos  | 02 Nos                  | M/R                   |
|               | <ul style="list-style-type: none"> <li>➤ Basement floor.</li> </ul>               | -NA-  | -NA-                    | -NA-                  |
|               | <b>b) Width of Staircase</b>  |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>➤ Upper floors</li> </ul>                  | 1.50 m / 0.90 m   | 1.30 mtr & 1.28 mtr     | M/R                   |
|               | <ul style="list-style-type: none"> <li>➤ Basement floor</li> </ul>                | -NA-  | -NA-                    | -NA-                  |
|               | <b>c) Protection of exits</b>   |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>➤ Fire check door</li> </ul>               | -NA-  | -NA-                    | -NA-                  |
|               | <ul style="list-style-type: none"> <li>➤ Pressurization</li> </ul>                | -NA-  | -NA-                    | -NA-                  |
|               | <b>d) No. of continuous staircase to terrace</b>                                  | -NA-  | -NA-                    | -NA-                  |
|               | <b>e) Width of corridor</b>   | 1.5 m   | Provided                | MR                    |
|               | <b>f) Door size</b>   | 1 m   | Provided                | MR                    |
| 3             | <b>Compartmentation.</b>  |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>• Fire check door.</li> </ul>              | -NA-  | -NA-                    | -NA-                  |
|               | <ul style="list-style-type: none"> <li>• Sealing of electrical shafts.</li> </ul> | -NA-  | -NA-                    | -NA-                  |
|               | <ul style="list-style-type: none"> <li>• Fire rating of shaft door.</li> </ul>    | -NA-  | -NA-                    | -NA-                  |
|               | <ul style="list-style-type: none"> <li>• Water curtain</li> </ul>                 | -NA-  | -NA-                    | -NA-                  |
|               | <ul style="list-style-type: none"> <li>• Fire dampers.</li> </ul>                 | -NA-  | -NA-                    | -NA-                  |
| 4             | <b>Smoke Management system.</b>   |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>• Basement</li> </ul>                      | 30 ACPH   | -NA-                    | -NA-                  |
|               | <ul style="list-style-type: none"> <li>• Upper floors</li> </ul>                  | 12 ACPH   | NA                      | -NA-                  |
| 5             | <b>Fire Extinguishers.</b>  |   |                         |                       |
|               | <ul style="list-style-type: none"> <li>• Total numbers</li> </ul>                 |   | 18 No's                 | MR                    |
|               | <ul style="list-style-type: none"> <li>• Types</li> </ul>                         | ABC/ Co2  | ABC type                | MR                    |
|               | <ul style="list-style-type: none"> <li>• ISI Marking</li> </ul>                   | ISI Marked  | Provided                | MR                    |

|      |   |          |  |      |      |      |
|------|---|----------|--|------|------|------|
| 6    | <b>First Aid Hose Reels.</b><br><ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>  | 02 No's  | Provided & functional  | MR   |      |      |
|      |   | 30 m     | Provided & functional  | MR   |      |      |
|      |   | 5 mm     | Provided & functional  | MR   |      |      |
|      |   |          |  |      |      |      |
| 7    | <b>Automatic fire detection &amp; alarming system.</b>  |          |  |      |      |      |
|      | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
| 8    | <b>MOEFA</b>  | -NA-     | NA   | -NA- |      |      |
| 9    | <b>Public Address System</b>  | -NA-     | -NA-   | -NA- |      |      |
| 10   | <b>Automatic Sprinkler System</b>   |          |  |      |      |      |
|      | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | NA   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
| 11   | <b>Internal Hydrants.</b>   |          |  |      |      |      |
|      | <ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>  | -NA-     | 100 mm   | -NA- |      |      |
|      |   | -NA-     | 02   | -NA- |      |      |
|      |   | -NA-     | 02   | -NA- |      |      |
| 12   | <b>Yard Hydrants.</b>   |          |  |      |      |      |
|      | <ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>  | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
| 13   | <b>Pumping arrangements.</b>  |          |  |      |      |      |
|      | <ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul> | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | -NA-     | -NA-   | -NA- |      |      |
|      |   | 450 LPM  | Provided & functional  | MR   |      |      |
|      |   | 40 mtr   | Provided & functional  | MR   |      |      |
|      |   | Required | Provided & functional  | MR   |      |      |
|      |   | Required | Provided & functional  | MR   |      |      |
|      |   | 14       | <b>Captive water storage for fire fighting.</b>  |      |      |      |
|      |   |          | <ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> | -NA- | -NA- | -NA- |
| -NA- | -NA-  |          |  | -NA- |      |      |
| -NA- | -NA-  |          |  | -NA- |      |      |
| -NA- | -NA-  |          |  | -NA- |      |      |

|     |   |             |  |      |
|-----|---|-------------|--|------|
|     | • Overhead tank capacity.   | 10,000 Ltrs | Provided & functional                                    | MR   |
| 15  | <b>Exit Signage.</b>  | Required    | Provided   | MR   |
| 16  | <b>Provision of Lifts.</b>  |             |  |      |
|     | • Pressurization of lift shaft.   | -NA-        | -NA-   | -NA- |
|     | • Pressurization of lift lobby.   | -NA-        | -NA-   | -NA- |
|     | • Communication in lift car.  | -NA-        | -NA-   | -NA- |
|     | • Fireman's switch.   | -NA-        | -NA-   | -NA- |
|     | • Lift signage.   | -NA-        | -NA-   | -NA- |
| 17  | <b>Standby Power Supply</b>   | NA          | NA   | NA   |
| 18  | <b>Refuge Area</b>  |             |  |      |
|     | • Total area  | -NA-        | -NA-   | -NA- |
|     | • Location  | -NA-        | -NA-   | -NA- |
| 19. | <b>Fire Control Room.</b>   |             |  |      |
|     | • Detector system panel.  | -NA-        | -NA-   | -NA- |
|     | • Flow switch panel.  | -NA-        | -NA-   | -NA- |
|     | • PA system panel.  | -NA-        | -NA-   | -NA- |
|     | • Battery backup.   | -NA-        | -NA-   | -NA- |
|     | • Building floor plan.  | -NA-        | -NA-   | -NA- |
| 20. | <b>Special Fire Protection System for the Protection of special Risk, if any.</b> |             | ABC type fire extinguishers provided near electric panel | -NA- |

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 440 dated 27/08/2021

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2246 Dated 05/10/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please

*Ry*  
18/10/2021

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

~~DO (SD)~~

*Ry*  
18/10

*DeFO (P)*

*18/10*

As approved  
your signature

*ADDO (BCP)*

*ADDO (BCP)*  
*18/10*  
*U.S. cell*