

437

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**


No. F.6/DFS/MS/EH/2021/NDZ/ 304

Dated: 25/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Wood Apple Restaurant at Plot No. 3, Hargovind Enclave, Main Vikas Marg, Shahdara, Delhi-110032, comprised of basement, stilt, ground plus three upper floors (Restaurant running on ground floor only) owned/occupied by M/s A Unit of Wood Apple Residency was issued FSC vide letter no. F.6/DFS/MS/2018/NDZ/2449 dated 31/10/2018(for entire building). The restaurant building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 24/09/2021 in the presence of Sh. Arvind Rawat, Manager and that the premises is fit for occupancy Group 'D' "Assembly Building" (on ground floor only) with effect from 25/10/2021 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on..... 25/10/2021 .....at New Delhi by

  
(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

Copy to:-

1. The Dy. Health Officer,  
EDMC, Health Department  
Shahdara (South) Zone, Karkardooma,  
Shahdara, Delhi
2. Ms. Renu Malik,  
Wood Apple Restaurant,  
Plot No. 3, Hargovind Enclave,  
Main Vikas Marg, Shahdara,  
Delhi-110032

### CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate should not be treated for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL/National Building Code.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Wood Apple Restaurant Plot no. 3, Hargovind Enclave, Main Vikas Marg, Karkardooma, Delhi-110092
2. Building is comprised of : Basement, Stilt, G +3 ( Restaurant running on Ground floor only)
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/2018/NDZ/2249 dt- 31/10/2018
6. Fire Safety direction letter No. : Delhi Fire Service Act, 2007 and Rules 2010
7. Date of Inspection : 24/09/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Arvind Rawat, Manager
10. Year of Construction : 2010
11. Applicant's Letter No. : 2021090320014 dated 08/09/2021

| Sr. No | Minimum Standards on Fire Prevention and Fire Safety U/R33  | NBC Requirement                               | Provided at Site   | Remarks MR/NMR                                 |
|--------|---|---|--|--|
| 01     | Access to Building  |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>  | 6 m<br>N/A<br>N/A                             | 30 m<br>N/A<br>N/A   | MR<br>N/A<br>N/A                               |
| 02     | Number, Width, Type and Arrangement of Exits  |   |  |  |
|        | a. Number of Staircases   |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basement</li> </ul>  | 2 nos.<br>1 no.                               | 3 nos.<br>2 nos.   | MR<br>MR                                       |
|        | b. Width of Staircases  |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>   | 1.5 m & 1.25 m<br>1.25 m                      | 1.5 m, 0.75 m (stilt to ground) & 1.15 m (Basement to terrace)<br>1.15 m & 2.0 m | MR (Accepted Earlier)<br>MR (Accepted Earlier) |
|        | c. Protection of Exits  |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>   | N/A<br>N/A                                    | N/A<br>N/A   | N/A<br>N/A                                     |
|        | d. No. of Continuous Staircases to Terrace  | 1 no.   | 1 no.  | MR   |
|        | e. Width of Corridor  | N/A   | N/A  | N/A  |
|        | f. Door Size  | 2 m & 1 m                                     | 2 m ,1 m   | MR (Accepted Earlier)                          |
| 03     | Compartmentation  |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire dampers</li> </ul> | N/A<br>N/A<br>N/A<br>N/A<br>N/A               | N/A<br>N/A<br>N/A<br>N/A<br>N/A  | N/A<br>N/A<br>N/A<br>N/A<br>N/A                |
| 04     | Smoke Management System   |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>   | N/A<br>N/A                                    | N/A<br>N/A   | N/A<br>N/A                                     |
| 05     | Fire Extinguishers  |   |  |  |
|        | <ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>  | 10 nos.<br>ABC /CO <sub>2</sub><br>ISI marked | Provided<br>ABC/Co <sub>2</sub><br>ISI marked                                    | MR<br>MR<br>MR                                 |

N/A

|    |  |             |             |     |
|----|--|-------------|-------------|-----|
| 06 | First-Aid-Hose Reels                         |             |             |     |
|    | • Total numbers on each floor                | 1 no.       | Provided    | MR  |
|    | • Length of hose reel hose                   | 30 m        | Provided    | MR  |
|    | • Nozzle diameter                            | 5 mm        | Provided    | MR  |
| 07 | Automatic Fire Detection and Alarming System |             |             |     |
|    | • Type of detectors                          | N/A         | N/A         | N/A |
|    | • Location of main panel                     | N/A         | N/A         | N/A |
|    | • Location of repeater panel                 | N/A         | N/A         | N/A |
|    | • Alternate source of power                  | N/A         | N/A         | N/A |
|    | • Hooter' location                           | N/A         | N/A         | N/A |
| 08 | MOEFA  | N/A         | Provided    | MR  |
| 09 | Public Address System                        | N/A         | N/A         | N/A |
| 10 | Automatic Sprinkler System                   |             |             |     |
|    | • Basement                                   | Required    | Provided    | MR  |
|    | • Upper floor                                | N/A         | N/A         | N/A |
|    | • Sprinkler above false ceiling              | N/A         | N/A         | N/A |
| 11 | Internal Hydrants <b>Entire Building</b>     |             |             |     |
|    | • Size of riser/down-comer                   | 100 mm      | Provided    | MR  |
|    | • Number of hydrants per floor               | 1 no.       | Provided    | MR  |
|    | • Hose box                                   | 1 no.       | Provided    | MR  |
| 12 | Yard Hydrants                                |             |             |     |
|    | • Total number of hydrants                   | N/A         | N/A         | N/A |
|    | • Hose box                                   | N/A         | N/A         | N/A |
| 13 | Pumping Arrangements. <b>Entire Building</b> |             |             |     |
|    | ➤ Ground Level                               |             |             |     |
|    | • Discharge of main pump                     | N/A         | N/A         | N/A |
|    | • Head of main pump                          | N/A         | N/A         | N/A |
|    | • Number of main pumps                       | N/A         | N/A         | N/A |
|    | • Jockey pump out put                        | N/A         | N/A         | N/A |
|    | • Jockey pump head                           | N/A         | N/A         | N/A |
|    | • Standby pump out put                       | N/A         | N/A         | N/A |
|    | • Standby pump head                          | N/A         | N/A         | N/A |
|    | • Auto starting /manual stopping             | N/A         | N/A         | N/A |
|    | • Pump house access                          | N/A         | N/A         | N/A |
|    | ➤ Terrace Level                              |             |             |     |
|    | • Discharge of pump                          | 450 LPM     | Provided    | MR  |
|    | • Head of the pump                           | 40 m        | Provided    | MR  |
|    | • Power supply                               | Required    | Provided    | MR  |
|    | • Auto starting of pump                      | Required    | Provided    | MR  |
| 14 | Captive Water Storage for Fire Fighting      |             |             |     |
|    | • Underground tank capacity                  | N/A         | N/A         | N/A |
|    | • Draw-off connection                        | N/A         | N/A         | N/A |
|    | • Fire service inlet                         | N/A         | N/A         | N/A |
|    | • Access to tank                             | N/A         | N/A         | N/A |
|    | • Overhead tank capacity                     | 5,000 Ltrs. | 5,000 Ltrs. | MR  |
| 15 | Exit Signage                                 | Required    | Provided    | MR  |

N/12


|    |   |     |          |     |
|----|---|-----|----------|-----|
| 16 | Provision of Lifts  |     |          |     |
|    | <ul style="list-style-type: none"> <li>• Pressurization of lift shaft</li> <li>• Pressurization of lift lobby</li> <li>• Communication in lift car</li> <li>• Firemen's grounding switch</li> <li>• Lift signage</li> </ul> | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
| 17 | Standby Power Supply  | N/A | Provided | MR  |
| 18 | Refuge Area   |     |          |     |
|    | <ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>  | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
| 19 | Fire Control Room   |     |          |     |
|    | <ul style="list-style-type: none"> <li>• Detector system panel</li> <li>• Flow switch panel</li> <li>• PA system panel</li> <li>• Battery backup</li> <li>• Building floor plans</li> </ul>                                 | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
|    |   | N/A | N/A      | N/A |
| 20 | Special Fire Protection Systems for Protection of Special Risks, if Any:  | N/A | N/A      | N/A |

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.

*(Signature)*  
 (Nagender Singh)  
 ADO (Shahdara)

Dy. CFO (NDZ)

*(Signature)*  
 21/10/21



ADDO (Shah) FT letter is placed for signatures please

*(Signature)*  
 25/10

Dy. CFO (NDZ)

*(Signature)*  
 25/10/21

*(Signature)*