

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/Banq./WZ/2021/ 515

Dated: 21/10/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Wedding Opera (A Unit of S.G. Hospitality) Banquet Hall, located at B – 9, Ground Floor, Industrial Area, Lawrence Road Delhi -110035 was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/Banquet/2018/2523 dated 12.11.2018. The said premises was re-inspected by the officer concerned of this department on 06.10.2021 in the presence of Sh. C. K. Dua (Account Manager) & Sh. Dalbir Singh (Representative) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010, and that the premises/building is fit for occupancy class “Assembly” Group D (**Ground Floor only**) with effect from 21/10/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 21/10/2021 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Addl. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.
3. Sh. Gurmeet Singh, M/s Wedding Opera (A Unit of S.G. Hospitality) Banquet Hall, located at B – 9, Ground Floor, Industrial Area, Lawrence Road, Delhi -110035.

Following fire safety directives must be adhered to:-

1. **This FSC is valid for Ground Floor only**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Basement shall be kept closed.**
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

1. Name & address of the building: M/s Wedding Opera (A Unit of S.G. Hospitality) Banquet Hall Located at B – 9, Ground Floor, Industrial Area, Lawrence Road, Delhi -110035.
2. Type of Occupancy: Assembly at Ground Floor (In a building comprised of Basement (Closed by brick wall) + Ground Floor, Basement shall not be used)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Banq./2018/2523 dated 12.11.2018
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2018/4254 Dated 09/10/2018
6. Date of inspection : 06.10.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. C. K. Dua (Account Manager) & Sh. Dalbir singh (Respresentative)
9. Year of Construction : 2010-11
10. Applicant's online application no. : 2021082619101 dated 26.08.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements/letter dated 12.11.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 09 m 05 m NA 	<ul style="list-style-type: none"> 12mtrs On Road NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA Closed By Brick Wall 	<ul style="list-style-type: none"> NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA 1x210cm 	<ul style="list-style-type: none"> NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	4x2m	1 x 230 cm, 1 x 295 cm, 1 x 355 cm & 1 x 137 cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 07 nos. ABC & CO2 ISI marked 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR

	<ul style="list-style-type: none"> Total numbers on each floor 	04	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	Provided (Smoke Detectors)	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	Ground floor	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	Provided	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	Ground floor	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	NA	Provided	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	04	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw of connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	25,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fireman's Grounding 	NA	NA	NA

17	Standby power supply	Required	Provided	MR
18	Refuge Area	NA	NA	
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/Banq./2018/2523 dated 12.11.2018 is recommended under rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

S.P. Bhardwaj, ADO (WP)

[Signature]
5/8/10/21

~~DO/WEST~~

~~dy~~ 6/10

~~Defo (W2)~~

[Signature]
8/10/2021

~~ADO~~ ~~ADO~~

FT is put up for sanction ph

~~Defo W2~~

[Signature]
21/10/2021

[Signature]

ms/cell

D.O. (WEST)/237
DATED..7/10/2021