

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/Audi./2021/SZ/ 517

Dated: 22/10/2021

FIRE SAFETY CERTIFICATE

Certified that Arya Auditorium (Formerly Lalit Suri Auditorium) Des Raj Campus, C-Block, East of Kailash, New Delhi - 110065 comprised of Basement, Ground, & 01 upper floor was issued FSC by this department vide letter No. F.6/MS/DFS/Auditorium/2015/2173 dated 11/12/2015. The premises was re-inspected by the officers concerned of this department on 12/10/2021 in the presence of Mr. Rahul Heer and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly Building, Group-D" (Auditorium) as above with effect from 22/10/2021 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/10/2021 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICE

Copy to: -

1. Arya Auditorium (Formerly Lalit Suri Auditorium) Des Raj Campus, C-Block, East of Kailash, New Delhi - 110065
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry

INSPECTION REPORT

1	Name & Address of the Building	Arya Orphanage, Arya Auditorium (Formerly Lalit Suri Auditorium) Des Raj Campus, C-Block, East of Kailash, New Delhi - 110065		
2	Type of Occupancy	Group "D" Assembly Building (Auditorium)		
3	Building Comprised of	Small Basement, Ground + One Upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/Auditorium/2015/2173 dated 11/12/2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	12/10/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Rahul Heer		
10	Year of construction	2008-09		
11	Applicant letter No.	Gmail dated 17-10-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	9 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	02 Nos	MR
	➤ Basement floor.	Required	01 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	Required	1.72 mtr & 1.55 mtr	MR
	➤ Basement floor	Required	1.10 mtr	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 Nos	MR
	e) Width of corridor	Required	3.12 Mtr	MR
	f) Door size (Exits in hall)	GF- 04 nos FF- 02 nos	1.70, 1.5, 1.48, 1.68 & 1.68 m 1.48 & 1.63 m	MR Old case
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fun Provided	MR
	• Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	24 Nos	MR
	• Types	ISI marked	Co2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos	Provided & Functional	MR
	• Length of hose-reel hose.	30m	Provided & Functional	MR
	• Nozzle Diameter	5mm	Provided & Functional	MR

M/24

7	Automatic fire detection & alarming system. <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Smoke & beam type	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided DG set, UPS	MR
		Every floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors. Sprinkler above false ceiling 	Required	Provided & Functional	MR
		Required	Provided & Functional	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	150mm	Provided & Functional	MR
		02	Provided & Functional	MR
		02	Provided & Functional	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	05	Provided & Functional	MR
		05	Provided & Functional	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 			
		2800 LPM	Provided & Functional	MR
		60m	Provided & Functional	MR
		01	Provided & Functional	MR
		180 LPM	Provided & Functional	MR
		60 m	Provided & Functional	MR
		2800 LPM	Provided & Functional	MR
		60 m	Provided & Functional	MR
		Required	Provided & Functional	MR
		Required	Provided & Functional	MR
		450 LPM	Provided & Functional	MR
		40 m	Provided & Functional	MR
		Required	Provided & Functional	MR
		Required	Provided & Functional	MR
		14.	Captive water storage for fire fighting.	
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,00,000 Ltrs	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-

M/25

	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	Required	Provided	MR
	• Battery backup.	Required	Provided	MR
	• Building floor plan.	Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 825 dated 09/04/2021

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/MS/DFS/Auditorium/2015/2173 dated 11/12/2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

RK
13/10/2021

Signature of the Inspecting Officer
Name: Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~

RK
14/10/21

DyFO (S2)

F.T.

[Signature]
18/10

ADO (B/P)

As approved, F.T. letter is put up for your signature pl

RK
21/10/2021

DyFO (S2)

[Signature]

01