

C-15

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 296

Dated: 22/10/2021

FIRE SAFETY CERTIFICATE

Certified that the Beer on Wheels Located at First floor ,unit no 110, 111, 112 City Centre Sector – 12, Dwarka New Delhi, in a building comprised of 02 Basement + Ground + 05 Upper Floors (FSC issued to mall vide letter no F6/DFS/MS/Mercantile/2018/SZ/2741 Dated 21/12/2018) owned/ occupied By Beer on Wheels have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 13/10/2021 in the presence of Sh. Arvind (Director) and found that the said building that the premises is fit for occupancy class “ Assembly” Group D (**First Floor**) with effect from 22/10/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..22/10/21.. at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. Sh. Arvind (Director) Beer on Wheels First floor unit no 110, 111, 112 City Centre Sector – 12, Dwarka New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry

INSPECTION REPORT

1. Name & address of the building: Beer on Wheels First floor unit no 110, 111, 112 City Centre Sector – 12, Dwarka New Delhi.
2. Type of Occupancy : Class-D (Assembly)(**At First Floor in the Mall**)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/Mercantile/2018/SZ/2741 Dated 21/12/2018 (issued to mall)
5. Fire Safety directives L. No. :F6/DFS/MS/BP/2012/4026 Dated 26/10/2012
(issued to mall)
6. Date of inspection : 13/10/2021
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Arvind (Employee)
9. Year of Construction .
10. Applicant's letter No. : Application no. 2021100823716 dated 11/10/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases			
	• Upper floors	02	Provided (by Mall)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2x1.5m	Provided	MR

N15

3.	Compartmentation(Common With Mall)			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	Provided Provided Provided Provided Provided	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA 12 a/c per hour	NA Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	3 nos. each type ABC, CO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reel	Common with mall		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Required 36 m 5 mm	Provided by Mall Provided by Mall Provided by Mall	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke/ Heat Ground floor Required Required Required	Provided Provided at ground floor Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided by Mall	MR
10.	Automatic Sprinkler System (Common with mall)			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Required Required Required	Provided Provided Provided	MR MR MR
11.	Internal Hydrants: (common with the mall)			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	150 mm Required Required	Provided by Mall Provided by Mall Provided by Mall	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA NA	Provided by Mall Provided by Mall	NA NA

13.	Pumping Arrangements: Common with Mall			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	2850 Lpm	NA
		NA	88 mtr	NA
		NA	02 Nos.	NA
		NA	280 Lpm	NA
		NA	88 mtr	NA
		NA	2850 Lpm	NA
		NA	88 mtr	NA
		NA	Provided By Mall	NA
		NA	Provided By Mall	NA
		900lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting: Common with Mall			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	1,00,000 (By Mall)	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts Common with Mall			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided By Mall	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	Provided	NA
		NA	NA	NA
19.	Fire control room(Common with Mall)			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA

N/7

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA
-----	--	----	------------------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

~~DO/SO~~
14/10/21

Signature of the Inspecting Officer
Name UdaiVir Singh
Designation ADO DWK

~~DO/SO~~

^{n. spk}
~~about~~ about water tank capacity.

King
16/10

~~ADO (DWK)~~

Sir, It is submitted that:-

1) Capacity of terrace fire water tank is 10,000 ltrs, however underground water tank of 100,000 ltrs with proper pumping arrangement is provided in the building.

2. It is requested that the same may be considered.

'A'

~~DO/SO~~

'A' may be considered pl.

~~DO~~
24/10/21

King
21/10/21

DeFO/SZ

dh
22/10