

CS3

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2021/ 300

Dated: 25/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s M. Bar & Lounge , located at 11 Panchkuian Road, New Delhi, comprises of Ground, inside mezzanine and first floor, **but Restaurant running at ground floor only & storage at inside mezzanine** . The premises was inspected by officers concerned of this department on dated 04.10.21 in the presence of manager and found that the said premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly occupancy -Group D, Restaurant at ground floor only & storage at inside mezzanine** with effect from ~~25/10/21~~-----for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~25/10/21~~-----at New Delhi by.

  
(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Commissioner , North MCD , Civic Centre , New Delhi
2. The Addl. Commissioner of Police(Lic.), Ist floor, PS Defence Colony, New Delhi,  
**Online ID No. 2021070914937**dated 10/07/2021.
3. The Manager, M/S M. Bar & Lounge, located at 11, Panchkuian Road, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid only for ground floor.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is strictly prohibited.

## INSPECTION REPORT

1. Name & address of the building M/s M. Bar & Lounge  
11, Panchkuian Road, New Delhi.  
building is comprised of ground , mezzanine  
inside ground floor )& first floor
2. Type of occupancy:- Assembly occupancy Group-D , restaurant at  
ground & storage at mezzanine( inside ground  
floor)
3. Type of case:- New Cases
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 04/10/21
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) &  
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Manager
9. Year of construction:- 2010
10. Applicant's letter No:- ID no- 2021070914937dated 10/07/2021.& e -  
mail vipinrohilla656@gamil.com dated 21.09.21

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06 mtr.	09 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors (up to mezzanine )	01 nos	provided	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr	2.0 & 1.5 m	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	12 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A

	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	20,000liter	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection systems provided in the building were randomly tested, checked and found nonfunctional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, we may issue the FSC to said restaurant. Accordingly, DFA is put up for kind perusal and signature please

Signature of the Inspecting Officer

Signature of the Inspecting Officer

*Rajinder Atwal*  
6/10/21

Name:- Rajinder Atwal  
Designation:-DO(CD)

*Ravinder Singh*  
6/10/21

Name:- Ravinder Singh  
Designation:- ADO (CC)

*Sy. CFO (CD)*

*Rajinder Atwal*  
6/10/21

*CFO (CD) - 8/10/21*

*Director*

*What is the use of pressure flow should be planned on floor*

*gy*  
8/10/21

*DLF/10/21*

