

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ/ 873

Dated: 25/10/21

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya, New J.J. Hastal No.-2, Shiv Vihar, Uttam Nagar, New Delhi-110059, Comprised of ground plus one upper floor only, owned/occupied by Nigam Pratibha Vidyalaya was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2018/SZ/1170 dated 22/05/2018. The school building was re-inspected by the officer concerned of this department on dated 13/10/2021 in the presence of Principal and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and found that the building is fit for occupancy Group B 'Educational Building' with effect from 25/10/21..... for a period of three years, subject to conditions printed overleaf.

Issued on..... 25/10/21..... at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The Principal
Nigam Pratibha Vidyalaya, New J.J. Hastal No.-2,
Shiv Vihar, Uttam Nagar, New Delhi-110059.
2. Director of Education,
SDMC, Civic Centre, Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/L3
INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Vidyalaya, New J.J. Hastal No.-2, Shiv Vihar, Uttam Nagar, New Delhi-110059.
2. Building is comprised of : **Ground plus one upper floor only.**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/2018/SZ/1170 Dt.- 22/05/2018
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011
7. Date of Inspection : 13/10/2021
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Principal
10. Year of Construction : 2007
11. Applicant's letter No : Nil Dated -16/09/2021

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	06 m	MR
	Gate width	4.5 mtrs.	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	Two	Provided	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.50 & .75 m	1.50 & 1.30 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.	
g. Width of Corridor	1.50 m	2.30 m	MR	
h. Door Size	1 m	1.10 m (Double Door) few with single door	MR, being old case	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural ventilation provided	N.A.

N/LS

14	Captive Water Storage for Fire Fighting.	N.A.	N.A.	N.A.
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			N.A.
16	Provision of Lifts.	N.A.	N.A.	N.A.
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply		N.A.	N.A.
18	Refuge Area.	N.A.	N.A.	N.A.
	Total area	N.A.		
	Location			
19	Fire Control Room	N.A.	N.A.	N.A.
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC was issued vide letter no. F.6/DFS/MS/school/2018/SZ/1170 Dated- 22/05/2018 renewal under the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 is recommended.

Signature of the Inspecting Officer
 Name R K YADAV
 Designation ADO (JKP)

R K Yadav
 13/10/2021

DO (South West)

DO (2)
14/10/21
ES
AD (JKP)

F-T letter is put up for sign. please

R K Yadav
 21/10/2021