

C-50

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2021/ 299

Dated: 25/10/2021

FIRE SAFETY CERTIFICATE

Certified that M/s Pind Baluchi Restaurant & Bar, Located at, SS 2nd floor, Plot No-15-16, MLU, Sector – 6, Dwarka, New Delhi – 110075, is running at 2nd floor in a building comprised of Ground + 03 Upper Floors was issued FSC vide Letter no. F6/DFS/MS/EH/2018/SZ/2068 Dated 10/09/2018 The premises was re inspected by the officers concerned of this department on 12-10-2021 in the presence of Sh. Prem Prakash and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" **Group D (2nd Floor Only)** with effect from 25/10/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/10/21 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

- 
22/10/21
1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
 2. Sh. Prem Prakash M/s Pind Baluchi Restaurant & Bar, SS 2nd floor, Plot No-15-16, MLU, Sector – 6, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:-

1. **The FSC shall be null & void if terrace is being used for the restaurant.**
2. **The stairs lead to terrace must be kept free from any obstruction and free from lock & keys.**
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall be used as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/16

INSPECTION REPORT

1. Name & address of the building: M/s Pind Baluchi Restaurant & Bar,
Located at, SS 2nd floor, Plot No-15-16, MLU, Sector – 6, Dwarka, New
Delhi – 110075.
2. Type of Occupancy : Assembly “D” Restaurant
3. Type of Case : Renewal (Building comprised of G + 3
upper floor and Restaurant running at Second Floor)
4. Details of previous NOC : F6/DFS/MS/EH/2018/SZ/2068 Dated
10/09/2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/99/486 Dated 19/10/2015
6. Date of inspection : 12-10-2021
7. Name of the Inspecting Officer : Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Prem Prakash
9. Year of Construction : Before 2009
10. Applicant’s letter No. : Email Dated 29-09-2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/8	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18 m	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25m	1.25m (Including railing)	MR (Old case)
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	Required	01	MR
	f. Door Size			
		NA	NA	NA
		2 mtr	Provided (Including door frame)	MR (Old case)

N/A

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 ac per hour	Exhaust Fan Provided in Kitchen	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	4 nos.	Provided ✓	MR
	<ul style="list-style-type: none"> • Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	Smoke	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • 2nd Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm ✓	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1 ✓	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

N/18

13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm, 180 lpm	Provided	MR
		30 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

11/19

20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR
----	--	----------	--	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2018/SZ/2068 Dated 10/09/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;- The Terrace shall be used as per BBL. The FSC shall be null & void if terrace is used for restaurant.

Signature of the Inspecting Officer

Name Vikas Singh
Designation ADO/DWR

[Signature]
18/10/21

[Signature]
[Signature]

[Signature]
18/10/21

[Signature]
[Signature]

F.T.
[Signature]
21/10

A.O. (DWR)

bir At letter is put up for signature

[Signature]
[Signature]

[Signature]

[Signature]
22/10

MS = call