

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ/ 876

Dated: 25/10/21

FIRE SAFETY CERTIFICATE

Certified that the Sant R.L.D. Public School, 16A, Sainik Enclave, Sector 3, Mohan Garden, Uttam Nagar, New Delhi – 110059, Comprised of ground plus two upper floors owned/occupied by Sant R.L.D. Public School have complied with the fire prevention and fire safety requirements in accordance with the rule 35 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 05/10/2021 in the presence of Smt. Deep mala (Manager) of the school and found that the school building is fit for occupancy class B 'Educational Building' for with effect from 25.10.21. for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....25/10/21.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
kec

Copy to:-

1. The Principal ,
Sant R.L.D. Public School,
16A, Sainik Enclave, Sector 3, Mohan Garden, Uttam Nagar, New Delhi- 110059.
2. Director of Education,
GNCT of NCT of Delhi, Old Secretariat-54.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Sant R.L.D. Public School, 16A, Sainik Enclave, Sector 3, Mohan Garden, Uttam Nagar, New Delhi – 110059.
2. Building comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 07/10/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Deep Mala (Manager)
10. Year of Construction : 2009
11. Applicant's letter No. : Nil dated 02/09/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dt. of edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>06 m</p> <p>—</p> <p>N/A</p>	<p>06 m</p> <p>on road</p> <p>N/A</p>	<p>M/R</p> <p>MR</p> <p>N/A</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	<p>02 No.</p> <p>N/A</p>	<p>02 No's</p> <p>N/A</p>	<p>M/R</p> <p>No basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>1.5 & .75 m</p> <p>N/A</p>	<p>1.5 M & 1.20 M</p> <p>N/A</p>	<p>M/R</p> <p>No basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	d. No. of continuous staircases to terrace	N/A	One	N/A
	e. Width of Corridor	1.5 m.	2.18 M	M/R
	f. Door Size	1.0 M	1.0 M	M/R , old bldg. (Seating capacity less than 45 students in each class)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>N/A</p> <p>—</p>	<p>N/A</p> <p>Natural ventilation</p>	<p>N/A</p> <p>M/R</p>
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<p>06 no's</p> <p>ABC/CO2 type</p> <p>ISI marked</p>	<p>Provided</p> <p>Provided</p> <p>Provided</p>	<p>M/R</p> <p>M/R</p> <p>M/R</p>

6.	First-Aid Hose Reels	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One	Provided	M/R
			30 m	Provided	M/R
			5 mm	Provided	M/R
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
8.	MOEFA	N/A	N/A	N/A	
9.	Public Address System	N/A	N/A	N/A	
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
11.	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Provided	M/R	
		N/A	Provided	M/R	
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
	<ul style="list-style-type: none"> 450 LPM 40 mtrs Required N/A 	Provided	M/R		
		Provided	M/R		
		Provided	M/R		
		N/A	N/A		
		N/A	N/A		
14.	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		10000 ltrs	Provided	M/R	
15.	Exit Signage.	Required	Provided	M/R	

16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> • Battery backup 	N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was issued vide letter no. F6/DFS/MS/School/2015/909 dated 08/05/2015 has been complied.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures in accordance with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 it is recommended to grant Fire Safety Certificate.

R.K. Yadav
7/10/2021

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

D.O. (South West)

K. Singh
07/10/2021

By cfo (S2)

*Pl. speak on floors
A.O.P.K.P.*

*Spoken, there is only two floors over the
ground floor (G+2 floors). Inspection*

over please return to :