

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2021/ 474

Dated: 22/10/21

FIRE SAFETY CERTIFICATE

Certified that the M/s Shakun Guest House located at 723, Church Mission Road, Fatehpuri, Delhi, comprised of **Ground + 03 upper floors: Ground floor-** reception, **1st floor** -04 guest rooms with 04 beds, **2nd floor** - 04 guest rooms with 05 beds, **3rd floor** – 02 guest rooms with 03 beds, **total 10 guest room with 12 beds only**; was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/GH/NDZ/2018/1949 dated 23.08.2018. The building/premises was re-inspected by Assistant Divisional Officer (SPM) from this department on 18.10.2021 in presence of manager and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of “**Group A-1 (Residential – Guest House)**” for total **10 guest rooms with 12 beds (1st floor** -04 guest rooms with 04 beds, **2nd floor** - 04 guest rooms with 05 beds, **3rd floor** – 02 guest rooms with 03 beds) upto 3rd floor only, with effect from 22/10/21..... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 22/10/21.....at New Delhi by.


22/10/21

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025

ofc Rb
21-10

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi.
2. The Licensee, M/s Shakun Guest House at 723, Church Mission Road, Fatehpuri, Delhi.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1	Name & address of the building	M/s Shakun Guest House located at 723, Church Mission Road, Fatehpuri, Delhi.
2	Building is comprised of	Ground + 03 upper floors Ground floor- reception 1 st floor – 04 guest rooms 2 nd floor - 04 guest rooms 3 rd floor - 02 guest rooms
3	Type of occupancy	Residential Group A-1
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2018/1949 dated 23.08.2018
6	Fire Safety direction letter no.	Nil
7	Date of inspection	18.10.2021
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (SPM)
9	Name of the designation of officer from the building side	Manager
10	Year of construction	Old
11	Applicant's letter no.	Online application I.D. no. 2021090920773 dated 16.09.2021

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/NMR
1	Access to Building:			
	A Road width	NA (Spl. Area)	12 mtrs.	NA
	B Gate width	NA	NA	NA
	C Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of Staircases			
	a Upper floor	01 nos.	01 nos.	MR
	b Basement	NA	NA	NA
	B Width of Staircases			
	a Upper floor	80 cms	80 to 86 cms	MR
	b Basement	NA	NA	NA
	C Protection of Exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	NA	NA	NA
	F Door size	1 mtrs.	1 mtrs.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basement	NA	NA	NA
	B Upper floor	Natural/Mechanical	Natural	MR

5.	Fire Extinguisher:				
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	ISI marked	MR
6	First-Aid-Hose Reels:				
	A	Total numbers of each floor	01 no.	Provided	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors	CO detectors (required as per GN dated 27.05.2019)	Provided	MR
	B	Location of main panel	At ground floor reception	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements.				
	A	Ground Level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace Level			
	a)	Discharge of pump	225 LPM	225 LPM.	MR
	b)	Head of the pump	40 mtrs.	40 mtrs.	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	2500 ltrs	2500 ltrs	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		NA	NA	NA
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room:				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA

Meeting requirement (MR), Not meeting requirement (NMR), Not applicable (NA), Provided but not functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection. the guest house has also complied with the additional fire safety provisions mentioned in the gazette notification dated 27.05.2021 i.e CO detectors were found installed in all the rooms.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2018/1949 dated 23.08.2018 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name: Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CD)

[Handwritten signature]

18/12/21

[Handwritten signature]

[Handwritten signature]
18/10/21



[Handwritten note] For it put up for signatures ple