

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/CNG/2021/NDZ/ 532

Dated: 27/10/2021

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) at Geeta Colony, Delhi, comprised of basement plus ground floor (Basement Closed, Station operating at ground level only) owned/occupied by Indraprastha Gas Limited was issued FSC vide letter No. F.6/DFS/MS/CNG/NDZ/2018/1695 dated 19/07/2018. The premises have complied with the fire prevention and fire safety requirements in accordance with the earlier directives issued vide letter no. F.5(3A)/DFS/CNG/2000/121 dated 29/03/2000 and verified by the officer concerned of this department on 05/10/2021 in the presence of Sh. Jabar Singh, Manager and that the CNG Station is fit for occupancy class "Storage" (CNG Pump) with effect from ..27/10/2021... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....27/10/2021.....at New Delhi by


27/10/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



To,

Sh. Ajay Khatri,
(DGM-Fire & Safety),
IGL Bhawan, Plot No. 04, Community Center,
R.K. Puram Sector-09, New Delhi-110022

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. Basement shall not be used for any purpose and will be sealed with brick wall.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
10. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.

JN/19

INSPECTION REPORT

1. Name & address of the building : CNG Station at Geeta Colony, Delhi
2. Building is comprised of : Basement plus Ground floor(Basement Closed, Station operating at ground level only
3. Type of Occupancy : CNG Storage & Dispensing Unit
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/CNG/NDZ/2018/1695 dated-19/07/2018
6. Fire Safety direction letter No : F5/(3A)/DFS/CNG/2000/121 dt-29/03/2000
7. Date of Inspection : 05/10/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Jabar Singh, Manager
10. Year of Construction : 2005
11. Applicant's letter no. : IGL/F&S/2021/15/11/02 dt-01/09/2021

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	As Per Directives	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 m N/A N/A	30 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases in basement b. Width of Staircases	N/A N/A	Closed N/A	Closed N/A
03	Compartmentation	Required	Provided	MR
04	Smoke Management System.	Required	Provided	MR
05	Fire Extinguishers.			
	<ul style="list-style-type: none"> • DCP type 10 Kg. • DCP type 75 Kg. • CO₂ type 4.5 Kg. • IS Marking 	10 nos. 05 nos. 06 nos. ISI Marked	10 nos. 05 nos. 06 nos. ISI Marked	MR MR MR MR
06	First-aid-Hose Reels.			
	Total numbers on each floor <ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
07	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Alternate source of power • Hooter's location 	Gas Required Required Required	Provided Provided Provided Provided	MR MR MR MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A

N/20

13	Pumping Arrangements			
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the Pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
15	Exit Signage/ No Smoking Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby power supply.	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection systems			
	• CO ₂ DCP local application	Required	Provided	MR
	• Hand held explosive meter	02 nos.	Provided	MR

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.

Dy. CFO (NDZ)

for kind perusal of ^{IGL} undertaking at clus p! for approval p!
ADOMR
 12/10/21

Nagender Singh
 11/10/21
 (Nagender Singh)
 ADO (Shahdara)



CFO (NDZ)

ADOMR
 13/10/21

[Signature]
 13/10/21

[Signature]

F.T. p!
ADOMR
 13/10/21

ADOCs/wh FT letter is placed for signatures please
 22/10