

C-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ / 909

Dated: 29/10/21

FIRE SAFETY CERTIFICATE

Certified that the **Notre Dame School**, V.P.O Kair, Najafgarh, New Delhi-110043, comprised of ground floor plus three upper floors, owned/occupied by Notre Dame School was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2019/SZ/241 dated 30/01/2019. The School building was re-inspected by the officer concerned of this department on 25/10/2021 in the presence of Sh. Kirshan (Admin.) and found that Notre Dame School have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....29/10/21..... at New Delhi.


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Notre Dame School, V.P.O Kair, Najafgarh, New Delhi-110043

2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/11

INSPECTION REPORT

1. Name & address of the building : Notre Dame School, V.P.O Kair, Najafgarh, New Delhi-110043
2. Building is comprised of : Ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/241 dated 30/01/2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 25/10/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Kirshan (Admin.)
10. Year of Construction : 2009 & 2014-15
11. Applicant's letter No. : NDS/2021 dated 12/10/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 30/01/2019	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 m 4.5 m N/A	Provided Directly accessible from road N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m N/A	1.75 m each N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
		1.50 m	2.55 m	M/R
	e. Width of Corridor	1.0 m	1.28 m	M/R
	f. Door Size		(Double door)	
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	11 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR


6.	First-Aid Hose Reels	• Total numbers on each floor	Two	Provided	MR
		• Length of hose reel hose	30 m	Provided	MR
		• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system	• Type of detectors	N/A	N/A	N/A
		• Location of Main Panel	N/A	N/A	N/A
		• Location of Repeater Panel	N/A	N/A	N/A
		• Alternate source of power	N/A	N/A	N/A
		• Hooters' Location	N/A	N/A	N/A
8.	MOEFA		N/A	N/A	N/A
9.	Public Address System		N/A	Provided	N/A
10.	Automatic Sprinkler System	• Basement	N/A	N/A	N/A
		• Ground Floor	N/A	N/A	N/A
		• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants	• Size of riser/down-comer	N/A	N/A	N/A
		• Number of hydrants per floor	N/A	N/A	N/A
		• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants	• Total number of hydrants	N/A	N/A	N/A
		• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements	• Ground Level			
		➤ Discharge of main Pump	N/A	N/A	N/A
		➤ Head of Main pump	N/A	N/A	N/A
		➤ Number of main pumps	N/A	N/A	N/A
		➤ Jockey Pump out put	N/A	N/A	N/A
		➤ Jockey pump head	N/A	N/A	N/A
		➤ Standby Pump out put	N/A	N/A	N/A
		➤ Standby Pump Head	N/A	N/A	N/A
		➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
		➤ Pump House Access	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting	• Terrace level			
		➤ Discharge of pump	450 LPM	Provided	MR
		➤ Head of the pump	30 m	Provided	MR
		➤ Power Supply	Required	Provided	MR
		➤ Auto Starting of pump	N/A	N/A	N/A
15.	Exit Signage.	• Underground tank capacity	N/A	N/A	N/A
		➤ Draw-off connection	N/A	N/A	N/A
		➤ Fire service inlet	N/A	Provided	N/A
		➤ Access to tank	N/A	N/A	N/A
		• Overhead Tank capacity	10,000 ltrs	Provided	MR
		Required	Provided	MR	

N/12




				No Lift
16.	Provision of Lifts.			N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A



The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2019/SZ/241 dated 30/01/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)


 Dy CFO (S2) F.T.  26/10/2021
 28/10

A.D.O./SRP
 F.T. letter is put up for signature please
 M.S. Uppal  29/10/2021