

418

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2021/SZ/ 318

Dated: 29/10/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the name & style of **M/s Velvet Room** (A Unit of Red Food Works Pvt. Ltd) Ground & Mezzanine Floor at Plot No 3, EFGH- Block, LSC Masjid Moth, G.K Part-II, New Delhi -110048 is located in the building comprised of Basement, Ground, Mezzanine plus First floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 22/10/2021 in the presence of Mr. Bharat and that the premise is fit for occupancy class **Group-D Assembly** (Restaurant running at **Ground & Mezzanine Floor only**) with effect from 29 / 10 /2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 29 / 10 /2021 at New Delhi by

  
**(ATUL GARG)  
DIRECTOR**

Copy to: -

1. The Joint Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016. (Ref. MHA Portal ID 2021092822741 dated 28/09/2021)
3. **M/s Velvet Room** (A Unit of Red Food Works Pvt. Ltd) Plot No 3, EFGH- Block, LSC Masjid Moth, G.K Part-II, New Delhi -110048

**Conditions for the validity of Fire Safety Certificate: -**

1. This FSC is valid only for Ground & Mezzanine Floor in r/o M/s Velvet Room (A Unit of Red Food Works Pvt. Ltd)
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

**INSPECTION REPORT**

1	Name & Address of the Building	M/s Velvet Room (A Unit of Red Food Works Pvt Ltd) Plot No 3, Ground & Mezzanine Floor, EFGH- Block, LSC Masjid Moth, G K Part-II, New Delhi -48		
2	Type of Occupancy	Group-D-4 Assembly (Restaurant at Ground & Mezzanine Floor)		
3	Building Comprised of	Basement, (other Property) Ground, Mezzanine plus First Floor only		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	UBBL / NBC - 2016		
7	Date of Inspection	22/10/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Bharat		
10	Year of construction	2010		
11	Applicant letter No	MHA Portal ID 2021093022984 dated 30/09/2021		
S No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/NBC-2016	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	6 mtr	Provided	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	Number of Staircase	02 No's	02 Nos	MR
	Upper floors.	N/A	Other property	N/A
	Basement floor.			
	Width of Staircase			
	Upper floors	1.5 mtr each	1.50 mtr & 2 mtg	MR
	Basement floor	N/A	Other property	N/A
	Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	No. of continuous staircase to terrace	Required	Provided	MR
	Width of corridor	1.5 mtr	Provided	MR
	Door size	1.50 m each	1.50 & 1.50 mtr	MR
3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	12 ACPH	Other property	N/A
	Upper floors	12 ACPH	Provided	MR
5	Fire Extinguishers.			
	Total numbers	06 Nos	06 Nos	MR
	Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A

	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	Basement	N/A	Other property	N/A
	Ground floor & upper floor	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	100 mm	Provided	MR
	Number of Hydrant per floor	One	Provided	MR
	Hose box.	One	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	N/A	N/A	N/A
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	450 LPM	450 LPM	MR
	Head of pump.	40m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	N/A	N/A	N/A
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	20,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			
	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A

	Battery backup.	N/A	N/A	N/A
	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

*[Handwritten signature]*  
25/10

Signature of the Inspecting Officer  
Name: - Sh. Rajesh Kumar  
Designation: - ADO/BCP

DO (SD)

*[Handwritten signature]*  
26/10/21

DCFO (SD)

*[Handwritten signature]*  
26/10

C.F.O. (D. off)

*[Handwritten signature]*  
27/10/2021  
HTPL

DCP/SL

*[Handwritten signature]*  
27/10

ADP/SLD

As approved, F.S. letter is sent for your signature

*[Handwritten signature]*  
29/10/21

*[Handwritten signature]*  
29/10/2021