

C-35



FORM 'H'
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI

No.F6/DFS/MS/SZ/2021/ 315

Dated: 29/10/2021

FIRE SAFETY CERTIFICATE

Certified that the building M/S Drool Buzz (A unit of 4RS Hospitality Pvt. Ltd.) Located at Ground floor, Metro Commercial Space, Metro station, Sec – 11, Dwarka, New Delhi – 110075 in a building comprised of Ground + 1st Floor (Platform Area) **FSC issued to Sector 11 Metro Station vide letter no F6/DFS/MS/2021/SZ/499 Dated 13/10/2021** owned/ occupied By M/S Drool Buzz (A unit of 4RS Hospitality Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 13/10/2021 in the presence of Sh. Ravinder kumar Dhankhar and found that the said building that the premises is fit for occupancy class “ Assembly” Group D(**Ground Floor Only**) with effect from 29/10/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/10/21 at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service



Copy to:

1. The Dy Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
2. The Manager, M/S Drool Buzz (A unit of 4RS Hospitality Pvt. Ltd.) Located at Ground floor Metro Commercial Space, Metro station, Sec – 11, Dwarka, New Delhi – 110075

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/S Drool Buzz (A unit of 4RS Hospitality Pvt. Ltd.) Located at Ground floor Metro Commercial Space, Metro station, Sec - 11, Dwarka, New Delhi - 110075
2. Type of Occupancy : Class-D (Assembly)(Restaurant- Ground floor)
3. Type of Case : New ✓
4. Details of previous NOC : **F6/DFS/MS/2021/SZ/499 Dated 13/10/2021 issued to Sector 11 Metro Station**
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 13/10/2021
7. Name of the Inspecting Officer ; Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Ravinder kumar Dhankhar
9. Year of Construction : 2006
10. Applicant's letter No. : Email dated 11/10/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/7	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	12 mtr ✓	MR
	• Gate width	4.5 mtr	Directly accessible from road ✓	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	02 mtr & 1.5m ✓	Provided ✓	MR ✓
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	Provided	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR

5.	Fire Extinguishers			
	• Total numbers	04 Nos.	04 Nos.	MR
	• Types	ABC, CO2	ABC	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel			
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Reception	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	Battery backup	NA
	• Hooters' Location	NA	Provided	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	Ground floor	02	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements: Common with Metro Station			
	• Ground Level			
	• Discharge of main pump	NA	1800 lpm	NA
	➤ Head of main pump	NA	70 mtr	NA
	➤ Number of main pumps	NA	01	NA
	➤ Jockey pump out put	NA	180 lpm	NA
	➤ Jockey pump head	NA	70 mtr	NA
	➤ Standby Pump out put	NA	1800 lpm	NA
	➤ Standby Pump Head	NA	70 mtr	NA
	➤ Auto Starting/Manual stopping	NA	Provided	NA
	➤ Pump House Access	NA	Provided	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Not provided	MR as pump at G. level at higher side
	➤ Head of the pump	40 m	Not providedDO.....
	➤ Power supply	Required	Not providedDO.....
	➤ Auto starting of pump	Required	Not providedDO.....
14.	Captive water Storage for fire fighting: Common with Metro Station			
	• Under ground tank capacity	NA	50000ltrs	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10000 ltrs	Not Provided	MR as Tank at G. level at higher side

- 176 -

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG set 125 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

1. M/S Droll Buzz (A unit of 4RS Hospitality Pvt. Ltd.) Located at Ground floor Metro Commercial Space, Metro station, Sec - 11, Dwarka, New Delhi - 110075
2. As per letter/ plan submitted by the applicant the area of the restaurant is 210 m²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be $117(210/1.8=116.6$ say 117) for whole restaurant.
4. The total seating capacity comes out be 117.

Note;- The FSC issued to the metro station sector 11 Dwarka ~~has been~~ renewed. If agreed, FSC to Droll Buzz may be issued as all the pumps provided in the premises are in good working condition & the restaurant is segregated from Metro station.

Signature of the Inspecting Officer
Name: Sh. Udaivir Singh
Designation : ADO (DWK)

Point No. 13 & 14 may be accepted pt.

[Signature]
16/10/21

[Signature]
18/10/2021

[Signature]
21/11/21

[Signature]
21/11/21

C.F.O.

[Signature]
28/11/21

FI 13

Anywhere

