

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2021/NDZ/ 547
Ref. ID No. 2021073016304

Dated: 02/11/2021

FIRE SAFETY CERTIFICATE

Certified that the Gobind Banquet Hall at 512/2-B, Jheel Khuranja, Geeta Colony Chowk, Delhi-110051, comprised of ground plus one upper floor (banquet running on ground floor) owned/occupied by Gobind Banquet Hall was issued FSC vide letter No. F.6/DFS/MS/2017/NDZ/322 dated 08/03/2017. The premises have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 31/08/2021 in the presence of Sh. Deshraj (Owner), and that the building is fit for occupancy class "D" 'Assembly building' with effect from 02/11/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf..

Issued on 02/11/2021 at New Delhi by



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

Sh. Deshraj Arora,
Gobind Banquet Hall,
512/2-B, Jheel Khuranja,
Geeta Colony Chowk, Delhi-110051

Copy to:-

1. The Commissioner, (To ensure occupancy in the building as detailed above)
EDMC, Headquarters,
419, Udyog Sadan, Patparganj Industrial Area,
New Delhi-110092
2. The Dy. Health Officer,
EDMC, Health Department,
Shahdara (South) Zone, Karkardooma,
Shahdara, Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate shall not be treated for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/30

INSPECTION REPORT

1. Name & address of the building : Gobind Banquet Hall, 512/2 -B, Jheel Khuranja, Geeta Colony Chowk, Delhi- 110051
2. Building is comprised of : G+1 (Banquet running on ground floor)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2017/NDZ/322 Dated 08/03/2017
6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/2202 dated- 10/09/13
7. Date of Inspection : 31/08/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Deshraj (Owner)
10. Year of Construction : 1976
11. Applicant's Application No. : 2021073016304, Dated- 02/08/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m N/A N/A	17 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	02 nos. N/A	02 nos. N/A.	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	1.5 m N/A	1.5 m each N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	MR
	f. Door Size	02 m	3.2m, 2m, 2m	MR
	g. No. of door	02 nos.	03 nos.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	03 nos. ABC /CO ₂ ISI marked	08 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm.	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting/manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	Required	Co ₂ local application panel provided	MR

Keeping in view the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of the Delhi Fire Service Rules, 2010.

Received on 21/9/21

(Signature)
 (Nagender Singh)
 ADO (Shahdara)

Dy. CEO (NDZ) *F.A. PI.*

(Signature)
 27/9/21



ADOCshah) FT letter is placed for signatures please

Dy. CEO (NDZ) Sir May like to see before issue! *5/10*

Director *(Signature)*
 13/10/2021

1- what is the activity of 1st floor.

2- 1st floor is connected from ground for internally & externally

(Signature)
 ADOCSHAH)

(Signature)
 13/10/21

(Signature)
 13/10/2021