

C76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/WZ/2021/ 321

Dated: 01/11/2021

FIRE SAFETY CERTIFICATE

Certified that the M/S MC Donald's Restaurant Located at 23, West Punjabi Bagh, central Market, New Delhi -110026 was issued Fire Safety certificate vide letter No. F6/DFS/MS/EH/2018/WZ/2656 dated 10/12/2018 for Basement, Ground & 1st Floor in a Building comprised of Basement, Ground & 03 Upper Floor. The Premises was re-inspected of the officer concerned of this department on 21/10/2021 in the presence of Sh. Sidharth and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said Floor is fit for occupancy class "Assembly" Group D (Basement, Ground & First Floor Only) with effect from 01/11/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. conditions mentions below

Issued on01/11/21... at New Delhi by.



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

oc

- Copy to: - 1. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi.
2. The Owner/ Occupier M/S MC Donald's Restaurant Located at 23, West Punjabi Bagh, Central Market, New Delhi -110026
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. This NOC is valid for Basement, Ground & 1st Floor only.

INSPECTION REPORT

1. Name & address of the building : Mc Donalds family restaurant located at 23, West Punjabi Bagh, Central Market, New Delhi
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2018/WZ/2656 dated 10/12/2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 21/10/2021
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Sh. Sidharth
9. Year of Construction : 2006-2007
10. Applicant's letter No. : Online application ID No. - 2021092422398 dated 24/09/2021

The said restaurant is running at Basement + Ground + first Floor in a Building comprised of Basement+ Ground +03 Upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement as per Insp. Dtd-26/11/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	Old Case	90 cm	MR being Old Case
	• Basements	Old Case	90 cm	MR being Old Case
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NR	NR	NR
	g. Door Size	Old Case	1.5 mts	MR being Old Case
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	10	12 Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mts	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	No False ceiling	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NR	NR	NR
	• Number of hydrants per floor	NR	NR	NR
	• Hose Box	NR	NR	NR
12	Yard Hydrants.			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	Old Case	450 LPM & 220 LPM	MR
	➤ Head of the pump	45 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR

15
16 Provision
17
18

1


14.


off

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Keeping in view the deemed compliance of the minimum standards of fire prevention & fire safety required under the rules, the NOC Vide letter no. F6/DFS/MS/EH/2018/WZ/2656 dated 10/12/2018 recommended.


~~DO (check)~~


 Signature of the Inspecting Officer
 Name: Sarabjeet Singh
 Designation: ADO (MN)


 25/10/2024

238/DO/WO
 dt-25/10/2024


DCF (W2) - kare
 DCF (S2)

F.T.

 26/10

ADO (MN)

As F.T is put up for your personal & signature

M.S. 10/11


 29/10/2024